

Emergency

District: Fort Thomas District Code: 176 Facility Name: Woodfill Eelmentary School Code: 040

Grade Level Served: K - 5 Current Student Capacity: 306 District Organization Plan: P-12

1. DESCRIPTION AND SCOPE OF PROPOSED PROJECT

A. Check and complete the applicable items:

1          New Building  
2          Addition  
3 X          Renovation or Alteration (Describe) Repair of existing air-conditioning system with minor upgrades to add air-conditioning to four additional classrooms.

4          Relocatable Classroom. Number          Size           
5          Equipment/Furnishings Procurement (Describe)         

6          Other (Describe)         

7          Site (Complete the Following)  
a. Site Acquisition          Expansion          Number of Acres           
b. A site has been acquired in accordance with 702 KAR 4:050 regulations           
c. Location           
d. Proposed site currently owned by District (Y) (N)         

B. Compliance with 702 KAR 1:00 1/702 KAR 4:160

This application is being submitted for (refer to current plan):

1 Priority Category:           
2 Discretionary Item Number:           
3 Minor project not listed on Facility Plan:         

If None Of The Above Apply, Your Facility Plan Will Need To Be Amended

C Please provide a complete narrative of the proposed project.

Replacement of air-conditioning system at Woodfill Elementary School on an emergency basis, including replacing existing 50-ton chiller on the roof, providing 4 new ductless split units in each of 4 existing classrooms with matching condensing units on the roof, providing new electrical feeders for chiller and 4 ductless split units, and associated miscellaneous work

Local Board Order Authorizing Project And Narrative Justification Must Be Attached