

Templeman, Vivian

From: Kenner, Michael
Sent: Tuesday, May 22, 2012 12:41 PM
To: Todd Co Board Members; Templeman, Vivian
Subject: Sewer

Board Members:

I just spoke to Darrin concerning the sewer line. After running cameras through all possible lines that could be causing the problem, the damaged line is running from TCCHS to the tie in at the lift station. This is clay tile and the camera shows separation and leaking in several locations. There will also be a problem in that to completely repair the problem part of the track area and the bleachers are in the way. There is a way to complete the needed work but it will be rather costly though probably not as costly as having to repair/replace a track and bleachers. The cost very well may be in the \$30,000 range. I am asking Vivian to add this to the agenda for Thursday night so we can get the work done as quickly as possible.

Mike Kenner

Superintendent
Todd County Schools
205 Airport Road
Elkton, KY 42220
(270) 265-2436

Michael.kenner@todd.kyschools.us

Todd County Schools – Teaching, Caring, Serving