



BORE LOG	
Date Drilled: _____	
By MidSouth Geothermal	
00 -----	GRADE
00 TO 10 -----	
10 TO 16 -----	
16 TO 500 -----	
GROUND TEMP:	
THERMAL CONDUCTIVITY:	
THERMAL DIFFUSIVITY:	

- NOTES:
- GEO-THERMAL VAULT BASED ON MODEL PV6-4-10 WITH SUMP PUMP PROVIDED BY THE MANUFACTURER.
 - PROVIDE 1-1/4" PVC DISCHARGE FROM SUMP PUMP TO FRENCH DRAIN.
 - SEE ELECTRICAL DRAWINGS FOR POWER TO THE SUMP PUMP.
 - VAULT SHALL BE A COMPLETE PACKAGE WITH ALL PIPING AND VALVES IN-PLACE FROM MANUFACTURER.

1 GEO-THERMAL WELL LAYOUT
SCALE: 1/32" = 1'-0"

STEWART RICHEY | ENGINEERING
CONTRACTING GROUP

2137 GLEN LILY RD. | BOWLING GREEN, KY 42101
P: 270-842-5184 | F: 270-782-6654

"Providing Unsurpassed Service and Innovative Solutions through Our Exceptional People"

RBS DESIGN GROUP
Architecture

2137 GLEN LILY RD. | BOWLING GREEN, KY 42101
P: 270-842-5184 | F: 270-782-6654

JOB NUMBER	13001
DRAWN BY	ACE - WK
CHECKED BY	NW
DATE	3/31/16

REVISIONS	NO.	DATE

HENDERSON COUNTY SCHOOLS
SPOTTSVILLE ELEMENTARY SCHOOL
SPOTTSVILLE, KY

GEO-THERMAL SITE PLAN

SHEET NUMBER

G1.0

OF 4