



**PECK FLANNERY GREAM WARREN
ARCHITECTS, LLC**

Larry Gream, Architect

3.1

April 22, 2008

Chris Jones
Whittenberg Construction Company
P. O. Box 9429
Louisville, Kentucky 40209-9429

RE: New Rineyville Elementary School
Rineyville, Kentucky
Architect File No: 0508
BG# 05-116

Dear Chris:

I am in receipt of your COR #52 in the amount of \$15,229 to resurface the existing gymnasium roof. This proposal is acceptable. I will include this work in the next change order.

Please forward color charts with so that granule colors may be selected.

Please give me a call if you have questions regarding this transmittal.

Sincerely,

Larry Gream

c: Gary Milby
David Wyatt

Change Order Request

Detailed (with Breakdown of PCOs), Grouped by Each Number

#0348- Rineyville Elementary School
275 Rineyville School Rd
Rineyville, KY 40162

Project # #0348
Tel: 270-769-0938 Fax: 270-769-0204

WHITTENBERG CONSTRUCTION CO.

Change Order Request: 052

Date: 4/8/2008

To: Larry Gream
PECK FLANNERY GREAM WARREN INC.
112 North Main Street
Elizabethtown, KY 42701

From: Chris Jones
WHITTENBERG CONSTRUCTION CO.
P.O. Box 9429
4774 Allmond Av.
Louisville, KY 40209-9429

Description

Repair roof over gymnasium

Category

Status

In Review

Reference

Concord quote dated 4/2/08

Required By

Days Req

0

Amt Req

15,229

Notes

PCO No	Date	Reference	Amt Prop	Days Req	Category	Reason
Description						
Notes						

052	4/8/2008		15,229	0	Change Order	Consultant Directive
-----	----------	--	--------	---	--------------	----------------------

Item No	Item Description	Amt Prop	Reference
001	Install new roof coating over gymnasium (see Concord quote dated 4/2/08)	14,360	
002	WCC 5%	718	
003	Bond 1%	151	

Approved By:

Signature

Name

Date

Prolog Manager

Printed on: 4/10/2008 Whittenberg

Page 1



CONCORD ROOFING, L.L.C.

310 Floyds Fork Drive • Shepherdsville, KY 40165 • (502) 957-6063 • (502) 957-7715 - FAX

FAX

To: Mr. Chris Jones

From: Stephen M Golab

Company: Whittenberg Construction Co

Pages: 01 -Including Cover Sheet

Phone: (502) 361 - 8891

Date: 4/2/2008

FAX: (502) 368 - 9192

Re: Rineyville Elementary School

☐ Urgent ☒ For Review ☐ Please Comment ☒ Please Reply ☐ Please Recycle

• Comments:

Per Don Murray w/ Tremco Roofing:

Gymnasium Roof:

- 1) Make repairs to field membrane as needed.
- 2) Sweep up & remove loose granules from roof.
- 3) Install 1 coat of Tremco "One Coat Aluminum" roof coating over entire roof surface at a rate of 2.5 - 3 gallons per 100 square feet.

Materials & Labor: \$14,360.00

This is suppose to be forwarded to Mr. Dave Wyatt, Director of Facilities, Hardin County Schools

c: Don Murray (502) 243-3954 Fax