

# Hawk Buildings, Inc.

316 East Arcadia Avenue  
Dawson Springs, Kentucky 42408  
(270) 797-9050  
Fax - (270) 797-9050

August 12, 2016

Dawson Springs Independent School  
Mr. Lenny Whalen  
118 East Arcadia Avenue  
Dawson springs, Ky. 42408

RE: Roof Inspection for School Board Building

Mr. Whalen,

## FINDINGS:


Roof is old and brittle and should be replaced before winter, see pictures attached. Please note we have sealed around the vents in the pictures, wanted you to see what we did.

If you have any questions or concerns please don't hesitate to call me.

A handwritten signature in cursive script, appearing to read "Jim", written in dark ink.

Jim Haulk

D.S. School Board Bldg.



Shingle Roof old + brittle, several Tabs broken  
+ Missing

D.S. School Board Bldg



No boot AT ELECTRICAL riser, Needs sealed AROUND  
Sealed on 8/12/10

D.S. School Board Bldg



Need to Re-seal Around Risers  
Sealed on 8/12/16 -

D.S. School Board Bldg.



LOWER EAST CORNER has water damage, deck  
under shingles is rotten and needs replacing.