



## **PROGRESS REPORT**

**HARDIN COUNTY SCHOOLS  
JT ALTON MIDDLE SCHOOL – RE-ROOF PROJECT  
JT ALTON MIDDLE SCHOOL – TRUSS REPAIRS  
DISTRICT FACILITY PLAN UPDATE**

**Project No:** 201665  
**Date:** November 17, 2016  
**Time:** 6:00 PM  
**Location:** Hardin County Board of Education

---

### **TRUSS REPAIR STATUS**

All of the structural repairs have been completed as well as the wind-clip installations.

The final special inspection letter is attached to this report for reference.

### **REROOF UPDATE**

Work is ongoing, at the end of the week of 10/31 the panels will be installed on the Classroom Wing then moving over to the Gym area (Front Wall first).

All roof panels should be installed mid-November and detail work with final completion near first week of December.

Gym Wall Panels: All panels will be installed as of 11/1.

Sheet Metal Trim: This work is progressing hand in hand with the roof and wall panels.

### **DFP UPDATE**

All required KDE forms have been prepared, and submitted to KDE for review on 11/2.



35 Public Square  
Elizabethtown, KY 42701  
Phone: (270) 737-4226  
Fax: (270) 737-0441

November 2, 2016

Mr. Jack Hodges  
Building Inspector  
Department of Housing, Building, & Construction  
Division of Building Code Enforcement  
101 Sea Hero Road, Suite 100  
Frankfort KY 40601

Case No. 075545-000-A  
RE: **STRUCTURAL REVIEW REPORT**  
**James T. Alton Middle School Truss Repair**  
**Final Special Inspections Complete**  
100 Country Club Rd.  
Vine Grove, KY 40175  
2016-1383

Dear Mr. Hodges,

ICON Engineering has performed all final Special Inspections of the trusses repaired by Corbett Construction. All repairs, installation of hurricane clips, and corrective actions following previous special inspections reports have been completed. We therefore believe that the truss repairs were constructed in accordance with the project construction documents and that the building is now safe for occupancy.

Please let us know if you have any questions or need further clarification regarding the above.

Sincerely,

A handwritten signature in purple ink, appearing to read 'Michael S. Childers', written over a light blue circular stamp.

Michael S. Childers, PE  
President/Structural Engineer

