

**Proposed Change Orders for September 2018 Henderson County Board Meeting**  
**BG 15-016 SPOTTSVILLE ELEMENTARY RENOVATION/ADDITION**

5-3	Stewart Richey Structural Steel	\$1,050.00	installation of conduit and electrical boxes for receptacles and fire alarm devices inside the cafeteria columns in lieu of surface mounted receptacles. Plasma cutting of columns required in order to flush mount boxes at each location
-----	---------------------------------	------------	--