

AIA DOCUMENT G701-2000

Change Order

(Instructions on reverse side)

PROJECT:

(Name and address)

Hopkinsville High Pool
Air Handler Replacement
Hopkinsville, KY

TO CONTRACTOR:

(Name and address)

Mechanical Consultants, Inc.
PO Box 22025
Owensboro, KY 42304

CHANGE ORDER NUMBER: 1

DATE: 10/16/2019

ARCHITECT'S PROJECT NUMBER: BG # 19-024

CONTRACT DATE: 4/18/2019

CONTRACT FOR: General Construction

OWNER ☒ARCHITECT ☒CONTRACTOR ☒FIELD ☐OTHER ☐**THE CONTRACT IS CHANGED AS FOLLOWS:**

(Include, where applicable, any undisputed amount attributable to previously executed Construction Change Directives)

Replace conduit and wiring to the three exhaust fans in the pool area due to corrosion.

The original (Contract Sum) (Guaranteed Maximum Price) was \$ 153,800

The net change by previously authorized Change Orders \$ 0

The (Contract Sum) (Guaranteed Maximum Price) prior to this Change Order was \$ 153,800

The (Contract Sum) (Guaranteed Maximum Price) will be (increased) (decreased)

(unchanged) by this Change Order in the amount of \$ 7,425

The new (Contract Sum) (Guaranteed Maximum Price) including this Change Order will be \$ 161,225

The Contract Time will be (increased) (decreased) (unchanged) by ten (10) days.


The date of Substantial Completion as of the date of this Change Order therefore is 11/1/2019

NOTE: This Change Order does not include changes in the Contract Sum, Contract Time or Guaranteed Maximum Price which have been authorized by Construction Change Directive for which the cost or time are in dispute as described in Subparagraph 7.3.8 of AIA Document A201.

Not valid until signed by the Architect, Contractor and Owner.

WBW Engineering, Inc. Mechanical Consultants Christian Co. Board

ARCHITECT (Typed name)



(Signature)


Thomas Waldron, PE

BY

10/17/19

DATE

CONTRACTOR (Typed name)



(Signature)

Mark Sanders

BY

10/17/19

DATE

OWNER (Typed name)



(Signature)

Mary Ann Gemmill

BY

DATE



© 2000 AIA®
AIA DOCUMENT G701-2000
CHANGE ORDER

© 2000 The American Institute of Architects. Reproduction of the material herein or substantial quotation of its provisions without written permission of the AIA violates the copyright laws of the United States and will subject the violator to legal prosecution.

WARNING: Unauthorized photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

The American Institute
of Architects
1735 New York Avenue, N.W.
Washington, D.C. 20006-5292

KENTUCKY DEPARTMENT OF EDUCATION
DIVISION OF FACILITIES MANAGEMENT

CHANGE ORDER SUPPLEMENTAL
INFORMATION FORM

702 KAR 4:160

(Supplement to AIA G701 and G701/CMA Change Order Forms)

District: **Christian** District Code: **115** Facility Name: **Hopkinsville High School** School Code: **050**

BG #: **19-024** Project: **Hopkinsville High Pool Air Handler Replacement** Contract/Bid Package: **1**

Original Contract Sum: **\$ 153,800** Change Order Number: **1**

Requested Change Order Amount **\$ 7,425** Time Extension Required: ☒ Yes ☐ No

NOTE: All change orders shall be submitted with complete cost breakdown including materials, labor, overhead and profit, and any other descriptive drawings and information.

Contract change requested by:

- | | |
|--|---|
| <input type="checkbox"/> Local Board of Education | <input type="checkbox"/> General Contractor |
| <input checked="" type="checkbox"/> Architect/Engineer | <input type="checkbox"/> Construction Manager |
| <input type="checkbox"/> Code Enforcement Official | <input type="checkbox"/> Other: _____ |

Change Order Description and Justification:

This change is to replace conduit and wiring to 3 exhaust fans in the pool area. This needs to be replaced due to corrosion. This will allow each exhaust fan to have a dedicated circuit to keep the wiring from the VFDs separate as required by the VFD manufacturer.

Cost Benefit to Owner:

More cost effective to replace this as the AHU is being installed. The new conduit will be PVC so the chemicals in the pool area will not harm the conduit.

Have contract unit prices been utilized to support the cost associated with this change order?

☐ Yes ☒ No

Is the cost for this change order supported by an alternate bid or competitive price quote(s)?

☐ Yes ☒ No

Does this change order effect the total Architect/Engineer design fee for this project? ☐ Yes ☒ No

Current A/E Contract Amount: \$ _____


Fee Amount for this change +/-: \$ _____

New A/E Contract Amount: \$ _____

Board of Education Designee Signature

Date

Attach additional pages if necessary



MECHANICAL CONSULTANTS INC.

MECHANICAL CONTRACTOR

7727 Old Ky 81 Owensboro, Ky 42301
Phone: 270-785-9505 Fax: 270-785-9212
msanders@mci-mechanical.com

October 15, 2019

MCI job # 39121 CO # 01

WBW Engineering
3000 Canton Pike
Hopkinsville, KY 42240
Attn: Thomas Waldron

Re: Electrical conduits over pool

Dear Thomas,

Per your request we have priced replacing the conduit and wiring to the three pool area exhaust fans due to corrosion. Each fan will have a dedicated conduit run to keep the wiring from the VFDs separate as required by the VFD manufacture. The conduit will be PVC so the chemicals in the pool area will not affect the conduit.

Total price \$ 7,425

Material \$ 2,825

Labor\$ 4,600

Sincerely,
Mechanical Consultants Inc.

Mark Sanders
President