



Figg Alley

E Martin Luther King Blvd

Elementary School

Gas Main

Dorm 2nd floor

Simplex/Grinnell Protection Service Monitoring
Simplex system
No sprinkler system

Simplex Panel - local alarm
Dry sprinkler system

304 Lee Hall
Vacant

152 Board of Education

Simplex panel
Monitoring into call
Darville B.O.D.

301 Walker Hall
Dorm

Electric utility disconnect
Bldg 301

Jacob Hall PIV

306
Vacant

Simplex panel - local alarm
No sprinkler system
No gas

303 Jacob Hall

Simplex Panel - local alarm
Dry sprinkler system
No gas

308
Grow Hall
Cafeteria

Kitchen fire suppression system
Simplex panel - local alarm
No sprinkler system

Electric utility Bldg 303

Electric utility disconnect
Bldg 302

Gallaudet St

Brady-Thomas PIV

310
Vacant

Simplex panel - local alarm
No sprinkler system
No gas

309 Fiscal Plant

Boiler

Electric utility disconnect
Bldg 309

Gas main to
308 Grow Hall
302 Argo McClure

302 Argo McClure

CTE School

312
Vacant

Simplex panel - local alarm
No sprinkler system
To become fiscal plant est. time 2015
No Gas

378,000 Gal
Tanks for
Boiler

S 3rd St

S 2nd St

Gas Main to
Fiscal Plant

Jacob St

Parking lot

ORR Protection service - monitoring
Notifier panel
No sprinkler system
No gas
Multi purpose kitchen
2nd floor fire suppression system

320 Brady Hall

Dorm in
basement

316 Thomas Hall

Gym

Pool

ORR Protection service - monitoring
Notifier panel
No sprinkler system
No gas

First Southern Land LLC
No longer belongs to KSD

Hel-pad

Wet sprinkler system
ORR Protection service (emergency 24) - monitoring
Emergency 24 panel
No gas

*314 Kern Hall
Middle School &
High School

Wet sprinkler system
ORR protection service - monitoring
Notifier panel
No gas

318 McClure
Hall
Boys Dorm

John W D Bowling Ct

Fackler St

Electric Utility Disconnect Pole
Bldgs - 152, 304, 306, 308, 310,
312, 314, 316, 318, 320

PIVFC

Hydrant

