

DECO
ARCHITECTS

Somerset, Kentucky . (606)307-2561
www.decoarchitects.co

SKY
ENGINEERING

MECHANICAL • ELECTRICAL • PLUMBING

(270)-599-0182

1830 DESTINY LANE, SUITE 113 . BOWLING GREEN, KY

ACT JUSTLY . LOVE MERCY . WALK HUMBLY

MICAH 6:8

PENDING

SITE

SEWELL INSPECTIONS,
TESTING AND ENGINEERING

PO BOX 22651
NASHVILLE, TN 37202
PHONE (270) 779-3161

PENDING

PROJECT ARCHITECT

MEP CONSULTANT

STRUCTURAL ENGINEER

CIVIL ENGINEER

GENERAL CONTRACTOR



GENERAL SERIES (DECO ARCHITECTS)

- G1.00 COVER SHEET
G3.00 GENERAL NOTES
G4.00 LIFE SAFETY PLAN

CIVIL SERIES (SEWELL INSPECTIONS
TESTING AND ENGINEERING)

- C6.00 PAVEMENT REPAIRS &
IMPROVEMENTS

DEMOLITION SERIES (DECO ARCHITECTS)

- D1.00 DEMO FLOOR PLANS
D1.01 ENLARGED DEMO PLANS

ARCHITECTURAL SERIES (DECO
ARCHITECTS)

- A1.00 FIRST FLOOR PLAN
A1.01 ENLARGED PLANS
A3.01 WALL SECTIONS
A4.00 SCHEDULES
A4.01 DOOR AND WINDOW DETAILS
A5.00 ADA DETAILS
A5.01 ADA DETAILS

MECHANICAL SERIES (SKY ENGINEERING)

- M1.00 MECHANICAL DEMO PLAN
M1.01 MECHANICAL ROOMS ENLARGED
NEW/DEMO PLANS
M2.00 MECHANICAL NEW PLAN

ELECTRICAL SERIES (SKY ENGINEERING)

- E0.01 ELECTRICAL LEGENDS
E1.00 ELECTRICAL ENLARGED AREA C&D
E1.01 ELECTRICAL ENLARGED AREA C&D
E1.02 ELECTRICAL DEMO PLAN C&D
E1.03 ELECTRICAL POWER AND LIGHTING
AREA C&D

PLUMBING SERIES (SKY ENGINEERING)

- P1.01 PLUMBING ENLARGED FLOOR PLAN
P1.02 PLUMBING ENLARGED FLOOR PLAN

NOTE TO PLAN REVIEWER

THE INTENT OF THE PROJECT IS TO CONSTRUCT A *building type* TO SERVE AS A *building type* FOR *client name*. *describe building*.

OCCUPANCY.....X-X
CONSTRUCTION TYPE.....X-X
BUILDING AREA (ALL AREA UNDER ROOF)
FIRST FLOOR.....XX,XXX SQFT TOTAL

STORIES ABOVE GRADE.....1
HEIGHT ABOVE GRADE.....XX FEET

ALLOWABLE H&A PER 2018 KBC CHAPTER 5"
HEIGHT.....2 STORIES (20 FT) (SEE)
AREA.....9,500 SQFT (SEE)

OCCUPANT LOAD.....XX OCCUPANTS
ALLOWABLE FIRE AREA PER SECTION 903.2.1.3.....XX SQFT (SEE)
FIRE SUPPRESSION.....XX SPRINKLER (SHOP DRAWINGS PROVIDED BY OTHERS)
FIRE RATINGS.....XX HOUR SEPARATION AT SHARED WALLS
FIRE ALARM REQUIRED PER SECTION 907.2.1.....XX MANUAL BOXES NOT REQUIRED. NOTIFICATION SYSTEM
REQUIRED. (SHOP DRAWINGS TO BE PROVIDED BY OTHERS)

SMOKE DETECTOR REQUIRED.....NO
ALLOWABLE LENGTH OF DEAD END CORRIDOR PER 1018.4.....22'-0"
ALLOWABLE EXIT ACCESS TRAVEL DISTANCE PER TABLE 1016.2.....250'-0"
FIRE SEPARATION REQUIREMENTS PER TABLE 508.4.....1 HOUR AT FIT-UP BOUNDARIES
*SPRINKLER INCREASES UTILIZED

A₉ = [A1 x I1] + [A1 x I2]
A₉ = 38,000 SQFT

PROJECT LOCATION WITHIN CITY LIMITS.....YES/NO *name of city*
COUNTY.....*name of county*
NUMBER OF BUILDINGS IN THIS SUBMITTAL.....X
USE OF BUILDING(S).....*use*
BUILDING(S) IN THIS PROJECT IS/ARE.....☐ NEW FREESTANDING BUILDING
☐ NEW ADDITION TO EXISTING STRUCTURE
☐ RENOVATION ONLY
☐ RENOVATION & ADDITION

TOTAL AREA IN NEW BUILDING OR ADDITION.....N/A
NUMBER OF LEVELS (INCLUDING BASEMENT).....X
BASEMENT.....YES/NO
TOTAL AREA IN EXISTING BUILDING.....XXXX SQFT
DATE CONSTRUCTION TO BEGIN.....ASAP
ESTIMATED COMPLETION DATE.....ASAP

PLUMBING DATA

DESIGN CAPACITY OF BUILDING.....XXX MALES
XXX FEMALES
ARE RESTROOMS ACCESSIBLE TO PUBLIC.....YES/NO
ARE RESTROOMS ACCESSIBLE TO DISABLE.....YES/NO
SEWAGE DISPOSAL.....☐ MUNICIPAL
☐ PRIVATE
WATER SUPPLY.....☐ PUBLIC
☐ RILLED WELL
☐ CISTERN
☐ HAILED WATER
☐ ROOF WATER
☐ SPRING
☐ STEAM
☐ IF PRIVATE INDICATE THE TYPE AND DESIGN

TABLE OF CONTENTS

RECIPIENT:

CLIENT REVIEW.....☐
DHBC.....☐
LOCAL.....☐
KDE.....☒

DOCUMENT TYPE:

PERMIT/ABRIDGED.....☐
PRIVATE BID.....☐
PUBLIC BID.....☒
DESIGN-BUILD.....☐

SCOPE OF SERVICES

PROJECT DATA


THE STATE OF KENTUCKY ENFORCES THE FOLLOWING BUILDING CODES (PROVIDED BY THE DEPARTMENT OF HOUSING,
BUILDINGS AND CONSTRUCTION - DIVISION OF BUILDING CODES ENFORCEMENT):

2018 KENTUCKY BUILDING CODE (BASED ON THE 2015 INTERNATIONAL BUILDING CODE)
2018 KENTUCKY BUILDING RESIDENTIAL CODE (BASED ON THE 2012 INTERNATIONAL RESIDENTIAL CODE)
2015 INTERNATIONAL MECHANICAL CODE
2012 INTERNATIONAL FIRE CODE (NEW CONSTRUCTION PROJECTS, ONLY WHEN SPECIFICALLY REFERENCED BY THE BODY OF
KBC)
2012 INTERNATIONAL ENERGY CONSERVATION CODE
2009 ICC/ANSI A117.1 ACCESSIBLE AND USABLE BUILDINGS AND FACILITIES
KENTUCKY STATE PLUMBING LAW, REGULATIONS & CODE (815 KAR CHAPTER 20)
STATE BOILER REGULATION (KRS 236, 815 KAR 15)
2012 NFPA 1 FIRE PREVENTION CODE (AS DIRECTED BY 815 KAR 10.60 KENTUCKY STANDARDS OF SAFETY)
2010 NFPA 13 STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS
2010 NFPA 13B - SPRINKLER SYSTEMS IN ONE- AND TWO-FAMILY DWELLINGS AND MANUFACTURED HOMES
2010 NFPA 13R - STANDPIPE, HOSE SYSTEMS
2009 NFPA 54- NATIONAL FUEL GAS CODE
2017 NFPA 70- NATIONAL ELECTRICAL CODE
2010 NFPA 72- NATIONAL FIRE ALARM AND SIGNALING CODE
2012 NFPA 101- LIFE SAFETY CODE (HEALTH CARE FACILITIES)
GB-03-01- STRUCTURAL ENGINEERS ASSOCIATION OF KENTUCKY - SPECIAL INSPECTION GUIDELINES, THIRD EDITION, MARCH
2007.
THE ABOVE IS FOR REFERENCE ONLY AND IS ONLY REPRESENTATIVE OF THE MANY CODES AND STANDARDS CURRENTLY
USED IN KENTUCKY. FOR SPECIFIC APPLICATIONS NOT LISTED ABOVE, CONTACT THE DEPARTMENT OF HOUSING, BUILDINGS
AND CONSTRUCTION, DIVISION OF BUILDING CODES ENFORCEMENT AT (502) 573-0373 OR REFER TO CHAPTER 35 OF THE KBC.

KENTUCKY BUILDING CODES



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY.....FAB, KCC
DATE.....1/8/2020
SET.....CLIENT REVIEW



REVISION.....DESCRIPTION
X.....DDMMYYYY.....REVISION DESCRIPTION

REVISION	DESCRIPTION
X	DDMMYYYY



DECO
ARCHITECTS

Somerset, Kentucky
(606)687 - 9233
www.decoarchitects.co

TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE **COMPLETE**
SET OF CONSTRUCTION DOCUMENTS.
THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

COVER SHEET

G1.00


GENERAL

AN EDUCATIONAL FACILITY RENOVATION FOR TODD COUNTY MIDDLE SCHOOL ELKTON, KENTUCKY



1 OVERALL FIRST FLOOR - WATER BOTTLE FILLING STATION PLAN - KDE REFERENCE ONLY

SCALE: 1/16"=1'-0"



ELKAY
SPECIFICATIONS

Elkay EZH2O Bottle Filling Station & Versatile Bi-Level ADA Cooler
Filtered 8 GPH Light Gray
Model LZSTL8WSLK

PRODUCT SPECIFICATIONS

Elkay ezH2O® Bottle Filling Station & Versatile Bi-Level ADA Cooler, Filtered 8 GPH Light Gray, Chilling Capacity of 8.0 GPH (gallons per hour) of 50° F drinking water, based on 80° F inlet water and 90° F ambient, per ASHRAE 18 testing. Features shall include Hands Free, Visual Filter Monitor, Filtered, Green Ticker™, Laminar Flow, Antimicrobial, Real Drain. Furnished with Flexi-Guard® Safety Bubbler. Electronic Bottle Filler Sensor With Electronic Front And Side Bubbler Pushbar activation. Product shall be Wall Mount (On Wall), for indoor applications, serving 2 station(s). Unit shall be certified to UL 399 and CAN/CSA C22.2 No. 120. Unit shall be lead-free design which is certified to NSF/ANSI 61 & 372 (lead free) and meets Federal and State low-lead requirements.

Special Features:	Hands Free, Visual Filter Monitor, Filtered, Green Ticker™, Laminar Flow, Antimicrobial, Real Drain
Finish:	Light Gray Granite
Power:	115V/60Hz
Bubbler Style:	Flexi-Guard® Safety Bubbler
Activation by:	Electronic Bottle Filler Sensor With Electronic Front And Side Bubbler Pushbar
Mounting Type:	Wall Mount (On Wall)
Chilling Option*:	8.0 GPH
Full Load Amps	6
Rated Watts:	370
Dimensions (L x W x H):	36-3/4" x 19" x 39-1/16"
Approx. Shipping Weight:	104 lbs.
Installation Location:	Indoor
No. of Stations Served:	2

*Based on 80° F inlet water & 90° F ambient air temp for 50° F chilled drinking water.

Special Note: *Coming soon: The Elkay ezH2O you know and love is getting a fresh look, as shown here. In stock models may have prior logo design.

- Visual Filter Monitor: LED Filter Status Indicator for when filter change is necessary.
- Filter is certified to NSF 42 and 53 for lead, particulate, chlorine, taste and odor reduction, 3,000 gal. capacity.
- Green Ticker: Informs user of number of 20 oz. plastic water bottles saved from waste.
- Laminar flow provides clean fill with minimal splash.
- Silver Ion Antimicrobial protection on key plastic components to inhibit the growth of mold and mildew.
- Real Drain System eliminates standing water.

PART: _____ QTY: _____
PROJECT: _____
CONTACT: _____
DATE: _____
NOTES: _____
APPROVAL: _____

In keeping with our policy of continuing product improvement, Elkay reserves the right to change product specifications without notice. Please visit elkay.com for the most current version of Elkay product specification sheets. This specification describes an Elkay product with design, quality, and functional benefits to the user. When making a comparison of other products' offerings, be certain these features are not overlooked.

Elkay REV 07182019 2222 Camden Court © 2018 Page 1
LZSTL8WSLK Oak Brook, IL 60053 LZSTL8WSLK.spec.pdf



AMERICAN PRIDE. A LIFETIME TRADITION.
Use your family, the Elkay family has values and traditions that endure. For almost a century, Elkay has been a family-owned and operated company, providing thousands of jobs that support our families and communities.



Included with Product: Water Cooler (LZSTL8WSLC), Bottle Filler (LZWSR), Filter

Ships in multiple boxes.

PRODUCT COMPLIANCE

ADA & ICC A117.1
ASME A112.19.3/CSA B45.4
Buy American Act
CAN/CSA C22.2 No. 120
GreenSpec®
NSF/ANSI 42, 53, 61, & 372 (lead free)
UL 399



Complies with ADA & ICC A117.1 accessibility requirements when installed according to the requirements outlined in these standards. Installation may require additional components and/or construction features to be fully compliant. Consult the local Authority Having Jurisdiction if necessary.

Installation Instructions (PDF)

5 Year Limited Warranty on the refrigeration system of the unit. Electrical components and water system are warranted for 12 months from date of installation. **Warranty pertains to drinking water applications only. Non-drinking water applications are not covered under warranty.**

Warranty (PDF)

OPTIONAL ACCESSORIES

U1300C - WaterSentry Plus Replacement Filter (Bottle Filler)
LKAPREZL - Elkay Carafe Apron for EZ Gray
MLP200 - Accessory - In Wall Carrier (Bi-Level) for bi-level EZ, LZ, EMASF, LMASF, VRD, LVRC models
08551C - WaterSentry Filter Mounting Cover (Gray Granite)

DRINKING FOUNTAIN CALCULATIONS

OCCUPANCY ESTIMATE = 600

REQUIREMENTS:

- 2 WATER BOTTLE FILLING STATION MIN.
- 1 DRINKING FOUNTAIN OR BOTTLE FILLING STATIONS PER 75 STUDENTS.

600 PEOPLE / 75 FOUNTAINS = 8 DRINKING FOUNTAINS.

EXISTING PLAN:

- 4 NEW WATER BOTTLE FILLING STATION
- 12 BI-LEVEL WATER COOLERS WHICH EQUALS A TOTAL OF 16 WATER COOLERS.

PLUMBING LEGEND

BI-LEVEL BOTTLE FILLER / DRINKING FOUNTAIN COMBO, WITH FILTERED REFRIGERATED WATER DISPENSING OUT A PROTECTIVE COWL.

REGULAR BI-LEVEL DRINKING FOUNTAIN, WITH FILTERED REFRIGERATED WATER DISPENSING OUT A PROTECTIVE COWL.


ACCEPTABLE MANUFACTURERS: ELKAY, OASIS, & HAWS

***ALL DRINKING FOUNTAINS AND BOTTLE FILLERS HAVE BEEN INSTALLED BY OWNER

***FOR KY DEPARTMENT OF EDUCATION USE ONLY



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE THAT ALL PERMITS AND APPROVALS ARE OBTAINED PRIOR TO COMMENCING WORK.

BY ACE

DATE 01/07/2021

SET CLIENT REVIEW



REVISION DESCRIPTION

DDMMYYYY REVISION DESCRIPTION



DECO ARCHITECTS
Somerset, Kentucky
(606) 687-9233
www.decoarchitects.com

TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO BUILDING OFFICIALS AND CONTRACTORS WITH THE INTENT OF CONSTRUCTING NAMED PROJECT IS PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO THE DESIGN INTENT ESTABLISHED BY THE COMPLETE SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE SOLE PROPERTY OF DECO ARCHITECTS UNLESS EXPRESSLY TRANSFERRED THROUGH WRITTEN CONTRACT.

WATER BOTTLE FILLING STATION PLAN

G-2.00

PLUMBING

THE FOLLOWING NOTES ARE ADA GUIDELINES AND ARE FOR GENERAL INFORMATION ONLY. LISTED ITEMS DO NOT REPLACE OR AMEND FEDERAL, STATE OR LOCAL CODES. IN THE CASE OF CONFLICT IN THE REQUIREMENTS OF AUTHORITIES HAVING JURISDICTION, THE MOST RESTRICTIVE REQUIREMENTS SHALL GOVERN.)

THE FOLLOWING NOTES ARE A GUIDE LINES AND ARE FOR GENERAL INFORMATION ONLY. LISTED ITEMS DO NOT REPLACE OR DIMINISH FEDERAL, STATE OR LOCAL CODES. IN THE CASE OF CONFLICT IN THE REQUIREMENTS OF AUTHORITIES HAVING JURISDICTION, THE MOST STRINGENT REQUIREMENTS SHALL PREVAIL.

INTERIOR DOORS SHALL HAVE A 1/2" CLEAR UNDOORED OPEN SURFACE AREA AT THE STRESS/EDGE/PULLSIDE OF DOORS. INTERIOR DOORS SHALL HAVE 16" CLEAR AT THE STRESS/EDGE/PULLSIDE OF DOORS. PROVIDE 1/2" CLEAR UNDOORED OPEN SURFACE AREA AT THE STRESS/EDGE/PULLSIDE OF ALL DOORS. ALL LOCKSETS SHALL HAVE A LEVER HANDLE UNLESS NOTED OTHERWISE AND SHOWN ON DRAWINGS. LOCKS SHALL BE KEYS OR KEYS AND COMBINATION. LOCKS SHALL REQUIRE NO SPECIAL KNOWLEDGE OR EFFORT. THUMB-TURNS OR SEPARATE KEYS SHALL NOT BE ALLOWED ON EGRESS DOORS.

THRESHOLDS SHALL NOT EXCEED 1/2" IN HEIGHT AND SHALL HAVE A SLOPE NO GREATER THAN 1:2.

ALL ACCESSIBLE ENTRANCES SHALL BE PROVIDED WITH 18" CLEAR UNDOORED OPEN SURFACE AREA. CODES FOR ACCESSIBLE ENTRANCES SHALL BE KEYS OR KEYS AND COMBINATION. LOCKS SHALL REQUIRE NO SPECIAL KNOWLEDGE OR EFFORT. THUMB-TURNS OR SEPARATE KEYS SHALL NOT BE ALLOWED ON EGRESS DOORS.

GENERAL CONTRACTOR SHALL ALLOW FOR KNIGHT FINISH DIMENSIONS IN ADDITION TO STANDARD CONSTRUCTION DIMENSIONS IN ACHIEVING ALL ACCESSIBILITY CLEARANCES PER DRAWINGS AND/OR ADA GUIDELINES.

ALL VENTILATION SYSTEMS SHALL COMPLY WITH THE FOLLOWING:

STROBE LIGHTS TO BE DESIGNED TO HAVE A FREQUENCY OF NOT MORE THAN 60 FLASHES PER MINUTE.

1. THE GENERAL CONTRACTOR SHALL GUARANTEE THE WORK FOR ONE (1) YEAR AFTER SUBSTANTIAL COMPLETION OF THE WORK.

2. THE GENERAL CONTRACTOR SHALL PERFORM A ONE (1) YEAR WARRANTY WALK-THROUGH/INSPECTION WITH THE OWNER'S REPRESENTATIVE UPON REQUEST.

3. THE CONTRACTOR SHALL LEAVE A COPY OF REDLINED AS-BUILT DRAWINGS FOR THE OWNER/OWNER'S REPRESENTATIVE WITHIN 15 DAYS OF COMPLETION OF THE WORK. A COMPLETE SET OF CONSTRUCTION DRAWINGS SHALL BE PROVIDED TO THE OWNER UPON COMPLETION OF THE WORK AND BEFORE FINAL PAYMENT IS MADE. THE CONTRACTOR SHALL SECURE AND DELIVER TO THE OWNER ALL GUARANTEES AND/OR WARRANTIES ON ALL EQUIPMENT SUPPLIED AND/OR INSTALLED BY THE CONTRACTOR AND HIS/HER SUB-CONTRACTORS, AND ALL OPERATIONS/MAINTENANCE MATERIALS.

[illegible]

PRELIMINARY TO THE ARCHITECT. ALL SHOP DRAWINGS AND RELATED DRAWINGS TO BE REVIEWED AND APPROVED BY GC CORRESPONDENCE TO THE ARCHITECT.

10. THE MATERIALS AND EQUIPMENT ARE LEFT TO THE GENERAL CONTRACTOR, HIS SUBCONTRACTORS AND VENDORS TO FURNISH AND INSTALL AS NECESSARY FOR A COMPLETED PROJECT. ANY QUESTIONS SHOULD BE BROUGHT TO THE ATTENTION OF THE ARCHITECT.

11. IN CASE OF A BID PROPOSAL, THE GENERAL CONTRACTOR SHALL FURNISH ALL MATERIALS & EQUIPMENT SHOWN ON THE DRAWINGS AND SPECIFICATIONS. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES. VENDORS SHOULD SPELL OUT ALL LABOR/WORK/MATERIALS OR ANY SPECIAL ARRANGEMENTS TO BE PROVIDED BY OWNER OR OTHER VENDORS.

EXCEPTION: REFUSE TO LISTING OF ITEMS TO BE FURNISHED BY OWNER, AND ITEMS FURNISHED BY OWNER AND INSTALLED BY GC.

12. THE GENERAL CONTRACTOR AND ALL SUBCONTRACTORS ARE RESPONSIBLE FOR EXAMINING PERSONALLY AND CONDUCTING ANY RESEARCH OR INVESTIGATIONS THEY DEEM NECESSARY FOR THE PLANNING AND EXECUTION OF THEIR WORK. THE SUBMISSION OF ANY BID OR PROPOSAL SHALL BE CONSIDERED AN AGREEMENT TO CONDUCT SUCH RESEARCH AND INVESTIGATIONS IN ACCORDANCE WITH THE PLANS AND EXISTING CONDITIONS. CLAIMS MADE SUBSEQUENT TO THE PROPOSAL FOR THE MATERIALS AND/OR LABOR DUE TO THE INADEQUACY OF SUCH RESEARCH AND INVESTIGATIONS SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR. HOWEVER, PROPER EXAMINATION HAD BEEN MADE.

13. THE GENERAL CONTRACTOR AND ALL SUBCONTRACTORS AGREE THAT ANY UNFORESEEN CONDITION THAT IS DISCOVERED DURING THE BIDDING AND THE CONSTRUCTION PHASES WILL BE CALLED TO THE ATTENTION OF THE ARCHITECT/ENGINEER AND OWNER IMMEDIATELY FOR A SOLUTION TO BE DETERMINED.

14. THE OWNER WILL BE RESPONSIBLE FOR PAYMENT OF THE LOCAL AND STATE BUILDING DEPARTMENT ARCHITECTURAL PLAN REVIEW AND PERMITS. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING AND PAYING FOR ANY BUILDING OR TRADE PERMITS, LICENSES, AND INSURANCE. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR ANY OF THE FOLLOWING: PERMITS, CODE REQUIREMENTS, OTHERWISE AGREED UPON IN WRITING WITH THE OWNER.

15. BEFORE COMMENCING WORK, ALL SUBCONTRACTORS AS NECESSARY SHALL LOCATE AND MARK ALL EXISTING UTILITIES. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION AND PERSONAL SAFETY.

16. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES, UNDERGROUND AND OVERHEAD, IN ORDER TO TAKE ALL PRECAUTIONS FOR THEIR PROTECTION AND PERSONAL SAFETY.

17. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF THEIR RELATED CONSTRUCTION DEBRIS DAILY AND REMOVING THEM FROM THE JOB SITE OR PUTTING THEM IN JUMP BUSTER. EACH SUBTRADE WILL BE CHARGED FOR ANY RELATED EXPENSE TO DO THIS FOR THE PROJECT.

18. ALL EQUIPMENT, ROUGH DIMENSIONS AND UTILITY REQUIREMENTS ARE NOT DETAILD ON THESE DRAWINGS. THIS INFORMATION WILL BE SUPPLIED BY THE ARCHITECT/ENGINEER. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING CORRECT POWER CONNECTIONS. THIS INCLUDES ITEMS FURNISHED BY OTHER VENDORS AND THE OWNER. FAILURE TO DO SO SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR.

19. THE STRUCTURAL INTEGRITY OF THE PROPOSED BUILDING SHALL BE MAINTAINED BY ALL TRADES AT ALL TIMES.

20. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL CONSTRUCTION OF EXISTING FACILITIES, TEMPORARY UTILITIES, CONSTRUCTION DEBRIS COLLECTION AND REMOVAL, OR DUMPSTERS, AS COORDINATED WITH THE OWNER.

21. THE GENERAL CONTRACTOR AND SUBCONTRACTORS ARE RESPONSIBLE FOR PROVIDING ALL LABOR, TOOLS, EQUIPMENT, INCLUDING PUMP, FOR ALL UTILITIES TO BE INSTALLED OR REPAIRED.

[illegible][illegible]

1. CONSTRUCTION OPERATIONS ARE TO BE LIMITED TO AREAS DESIGNATED ON DRAWINGS.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES AND SHALL BE DILIGENTLY TO ASSIST THE GENERAL CONTRACTOR AND OWNER IN MEETING SUDAS TIME RESTRAINTS. BUT WILL NOT BE HELD RESPONSIBLE FOR ANY FAILURE TO DO SO. IT IS THE RESPONSIBILITY OF THE CONTRACTOR AND OWNER TO SET ATTAINABLE TIME RESTRAINTS FOR A SUCCESSFUL JOB.
3. UTILITIES SHALL BE PROTECTED BY THE CONTRACTOR AND OWNER AND SHALL BE PROTECTED AT ALL TIMES.
4. GENERAL CONTRACTOR AND SUB CONTRACTORS ARE TO INSURE THAT INCONVENIENCE TO THE GENERAL PUBLIC IS HELD AT AN ABSOLUTE MINIMUM.
5. GENERAL CONTRACTOR IS TO ASSUME FULL RESPONSIBILITY FOR THE PROTECTION AND SAFEEKEEPING OF PRODUCTS STORED ON SITE.
6. ANY WORK THAT CAUSES EXCESSIVE NOISE, DUST OR ODORS IS TO BE CONDUCTED IN A MANNER THAT IS APPROVED BY THE CITY OF CHICAGO AND THE ADJACENT COMMUNITIES.
7. COORDINATE USE OF PREMISES FOR WORK WITH THE LANDLORD AND OWNER PRIOR TO COMMENCEMENT OF WORK.
8. LIMIT USE OF SITE FOR WORK AND STORAGE TO AREAS DESIGNATED UNLESS SPECIFIC ADDITIONAL AREAS ARE ALLOWED IN WRITING BY THE LANDLORD AND OWNER.
9. TEMPORARY SANITARY FACILITIES FOR WORKERS OF ALL TRADES SHALL BE FURNISHED, INSTALLED AND MAINTAINED BY THE CONTRACTOR. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES AND SHALL BE DILIGENTLY TO ASSIST THE GENERAL CONTRACTOR AND OWNER IN MEETING SUDAS TIME RESTRAINTS. BUT WILL NOT BE HELD RESPONSIBLE FOR ANY FAILURE TO DO SO. IT IS THE RESPONSIBILITY OF THE CONTRACTOR AND OWNER TO SET ATTAINABLE TIME RESTRAINTS FOR A SUCCESSFUL JOB.
10. THE CONTRACTOR SHALL NOT USE DURING THE CONSTRUCTION OF THIS PROJECT, ALL FACILITIES AND SERVICES SHALL BE FURNISHED IN STRICT ACCORDANCE WITH THE CITY OF CHICAGO ORDINANCES.
11. ARRANGE WITH THE LANDLORD/OWNER A CONVENIENCE TIME TO PERFORM ALL WORK AND INSTALL TEMPORARY PROTECTED MEANS OF EGRESS FROM REQUIRED EXITS, INCLUDING TEMPORARY LIGHTING AND SAFETY DEVICES IN ACCORDANCE WITH THE CITY OF CHICAGO ORDINANCES.
12. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES AND SHALL BE DILIGENTLY TO ASSIST THE GENERAL CONTRACTOR AND OWNER IN MEETING SUDAS TIME RESTRAINTS. BUT WILL NOT BE HELD RESPONSIBLE FOR ANY FAILURE TO DO SO. IT IS THE RESPONSIBILITY OF THE CONTRACTOR AND OWNER TO SET ATTAINABLE TIME RESTRAINTS FOR A SUCCESSFUL JOB.

1. NO PROJECT ENVIRONMENTAL REPORT FOR ANY HAZARDOUS MATERIALS, INCLUDING RADON, SPILLED CHEMICALS, U.S.T.'S, ETC. WAS PROVIDED BY THE OWNER TO ARCHITECT, THEREFORE, THIS ARCHITECT ASSUMES NO LIABILITY SHOULD ANY CONDITION ARISE THAT COULD HAVE BEEN DISCOVERED OR PREVENTED HAD SUCH INVESTIGATIONS BEEN CONDUCTED.

2. THIS ARCHITECT HAS NO PROFESSIONAL LIABILITY FOR ANY CLAIMS REGARDING HAZARDOUS MATERIALS OR THE FAILURE TO PERFORM PROFESSIONAL SERVICES TO INVESTIGATE OR REMEDIATE THE PRESENCE OF SAID MATERIALS.

1. IF DESIGN INDICATED HEREIN IS IN ANY WAY NOT FULFILLED, THROUGH INTENTIONAL OR UNINTENTIONAL DEVIATION, THIS DRAWING SET WILL BE RENDERED NULL AND VOID AND ALL PROFESSIONAL, RESPONSIBILITY AND LIABILITY OF THIS ARCHITECT WILL BE IMMEDIATELY TERMINATED.

2. IT IS THE LEGAL AND PROFESSIONAL RESPONSIBILITY OF THE CLIENT AND ALL CONTRACTORS TO ADHERE FULLY TO THE SPECIFICATIONS AND REQUIREMENTS OF THIS DRAWING SET. ANY VIOLATION OF THESE SPECIFICATIONS SHALL BE CONSIDERED IMMEDIATELY FOR IMMEDIATE ACTION. DISCREPANCIES/ISSUES ARE NOT TO BE ADDRESSED WITHOUT WRITTEN APPROVAL FROM THIS ARCHITECT.

3. THIS ARCHITECT IS IN NO WAY RESPONSIBLE FOR THE SAFETY OF THE WORK SITE DURING CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO ENSURE THAT THE WORK SITE ADHERES TO ALL GUIDELINES AND SPECIFICATIONS OF THE GOVERNING AGENCIES. THE ARCHITECT DOES NOT HAVE ANY LIABILITY FOR THE SAFETY OF THE WORK SITE. THE ARCHITECT DOES NOT HAVE CONTROL, OVER OR CHARGE OF, NOR BE RESPONSIBLE FOR THE CONSTRUCTION METHODS, METHODS, TECHNIQUES, MATERIALS, OR EQUIPMENT USED IN THE CONSTRUCTION OF THE PROJECT. THE ARCHITECT DOES NOT HAVE ANY LIABILITY FOR THE PERFORMANCE OF THE WORK IN ACCORDANCE WITH THE REQUIREMENTS OF THE CONSTRUCTION DRAWINGS OR CONTRACTS, OR THE ACTIONS OF ANY SUBCONTRACTORS OR TRADE AGENTS OR EMPLOYEES OR ANY OTHER PERSONS OR ENTITIES PERFORMING PORTIONS OF THE WORK.

4. ALL CONSTRUCTION SHALL ADHERE FULLY TO APPLICABLE STATE AND LOCAL BUILDING CODES. IF ANY QUESTION AS TO SAID COMPLIANCE, THE ARCHITECT SHALL BE CONSULTED.

1. GENERAL CONTRACTOR TO ENSURE THAT CONSTRUCTION AND FINISHES ARE CLEAN, TRUE AND FREE OF IRREGULARITIES. DO NOT PROCEED WITH WORK UNTIL UNSATISFACTORY CONDITIONS HAVE BEEN CORRECTED. SHOULD A DEFECTOR WORK IN SEQUENCE AFTER THE PREVIOUS DEFECTOR, THE DEFECTOR MUST BE RESPONSIBLE FOR THE CORRECTION OF ANY DEFECTS. COMMENCEMENT OF WORK SHALL INDICATE THE LATER CONTRACTOR'S ACCEPTANCE OF PREDECESSOR'S WORK AS SATISFACTORY.

2. REPAIR AND REPLACE EXISTING SURFACES (IF APPLICABLE) PRIOR TO APPLICATION OF NEW FINISH.

3. ALL FINISHES SHALL BE LABELED (SUCH AS TAG, NAME, ETC.) OR ANY EQUIPMENT IDENTIFICATION, PERFORMANCE RATING, NAME OR NOMENCLATURE PLATED, SIGNED, EASY TO READABLE AND NOT PAINTED.

4. COORDINATE WITH OWNER'S DESIGNATED REPRESENTATIVE FOR DELIVERY AND PLACEMENT OF ALL FURNITURE AND WALL-HUNG EQUIPMENT.

5. PAINT AND OTHER FINISHES ARE TO BE APPLIED TO CREATE A SMOOTH, ACCEPTABLE FINISH. ALL FINISHES SHALL ADHERE TO A CONSISTENT PROFESSIONAL QUALITY.


[illegible][illegible]




SYMBOL LEGEND

ABBREVIATIONS

VICINITY MAP

SITE MAP





PLAN REVIEWER
IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY J. SEWELL
DATE 01/07/2021
SET CLIENT REVIEW



REVISION	DESCRIPTION
1	DDMM/YYYY REVISION DESCRIPTION

SITE

SEWELL INSPECTIONS
TESTING AND ENGINEERING

PO BOX 2246
NASHVILLE, TN 37202
PHONE (270) 779-3161

TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220

20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS FROM THE DRAWING BORDER.


COPYING THESE DOCUMENTS FOR DISTRIBUTION TO BUILDING OFFICIALS AND CONTRACTORS WITH THE INTENT OF CONSTRUCTING NAMED PROJECT IS PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO THE DESIGN INTENT ESTABLISHED BY THE COMPLETE SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE SOLE PROPERTY OF DECO ARCHITECTS UNLESS EXPRESSLY TRANSFERRED THROUGH WRITTEN CONTRACT.


PAVEMENT
REPAIRS &
IMPROVEMENTS

C-6.00

CIVIL




2 DEMO FLOOR PLAN - BASEMENT
1/16" = 1'-0"



1 DEMO FLOOR PLAN - FIRST FLOOR
1/16" = 1'-0"



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY FAB, KCC

DATE 1/8/2020

SET CLIENT REVIEW



REVISION DESCRIPTION

X DDMMYYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.


DEMO FLOOR PLANS

D1.00


DEMOLITION




1 DEMO ENLARGED PLAN - GYMNASIUM
1/8" = 1'-0"



2 DEMO ENLARGED PLAN - ENTRY RESTROOM
1/4" = 1'-0"



3 DEMO ENLARGED PLAN - GYM RESTROOMS
1/4" = 1'-0"



4 DEMO ENLARGED PLAN - WEST WING RESTROOMS
1/4" = 1'-0"

PRELIMINARY:
NOT FOR
CONSTRUCTION

DESIGN PROFESSIONAL

PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
(IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.)

BY
FAB, KCC

DATE
1/6/2020

SET
CLIENT REVIEW

SD DD CD

REVISION
X DDMMYYYY

DESCRIPTION
REVISION DESCRIPTION

DECO
ARCHITECTS

Somerset, Kentucky
(606) 687 - 9233
www.decoarchitects.co

TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.


COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

ENLARGED DEMO
PLANS

D1.01

DEMOLITION




1 FLOOR PLAN - FIRST FLOOR
1/16" = 1'-0"

2 FLOOR PLAN - BASEMENT
1/16" = 1'-0"

PRELIMINARY:
NOT FOR
CONSTRUCTION

DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING
(IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.)

BY FAB, KCC
DATE 1/6/2020
SET CLIENT REVIEW

SD DD CD

REVISION	DESCRIPTION
X	DDMM/YYYY REVISION DESCRIPTION

DECO ARCHITECTS
Somerset, Kentucky
(606) 687 - 9233
www.decoarchitects.co





TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO BUILDING OFFICIALS AND CONTRACTORS WITH THE INTENT OF CONSTRUCTING NAMED PROJECT IS NOT PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO THE DESIGN INTENT ESTABLISHED BY THE COMPLETE SET OF CONSTRUCTION DOCUMENTS.
THIS WORK IS PROTECTED UNDER THE UNITED STATES ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE SOLE PROPERTY OF DECO ARCHITECTS UNLESS EXPRESSLY TRANSFERRED THROUGH WRITTEN CONTRACT.


FIRST FLOOR PLAN

A1.00

ARCHITECTURAL



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY FAB, KCC

DATE 1/6/2020

SET CLIENT REVIEW



REVISION DESCRIPTION

DDMMYYYY REVISION DESCRIPTION

REVISION	DESCRIPTION
DDMMYYYY	REVISION DESCRIPTION



**TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020**

515 W MAIN ST
ELKTON, KENTUCKY 42220

20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.


COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

ENLARGED PLANS

A1.01

ARCHITECTURAL




1 OVERALL MECHANICAL DEMO PLAN

SCALE: 1/16"=1'-0"

0 8' 16' 32'

PRELIMINARY:
NOT FOR
CONSTRUCTION

DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY ACE
DATE 11/30/2020
SET CLIENT REVIEW

DD CD

REVISION DESCRIPTION
A DDMM/YYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220

20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.

COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

MECHANICAL DEMO
PLAN

M-1.00


ELECTRICAL




- 1 REMOVE EXISTING 3-WAY VALVE (CHILLED / HOT WATER) SERVED FOR SEASON CHANGE OVER AND RECONNECT CHILLER SUPPLY LINE DIRECTLY. REMOVE THE TEE FROM THE EXISTING CHILLED WATER SUPPLY LINE AND RECONNECT WITH STRAIGHT PIPE CONNECTION.
- 2 EXISTING PUMPS WILL BE SERVING CHILLED WATER PIPING ONLY. NEW PUMPS BE INSTALLED FOR HOT WATER PUMPING.



- 1 REMOVE EXISTING PUMP AS THERE WILL BE (2) PUMPS TO REPLACE THIS EXISTING PUMP WITH LEAD LAG OPERATION.



ELECTRICAL



SEE M101 FOR MECHANICAL ROOM DEMO / NEW PLANS

NEW HVAC NOTES:

- 1 NEW UNIT VENTILATORS TO BE INSTALLED AT SAME LOCATION OF REMOVED EXISTING. FULLY CLEAN EXISTING EXTERIOR LOUVER AND ANY BUILT UP DIRT / DEBRIS IN THE WALL CAVITY. NEW UNIT SIZE IS SMALLER THAN EXISTING, AS RESULT PORTION OF WALL CAVITY MAY NEED TO BE FILLED WITH INSULATION AND SHEETMETAL COVER. ON INTERNAL SIDE, EXPOSED WALL SHALL BE PAINTED TO MATCH EXISTING WALL COLOR. EXISTING PIPE CHASE TO BE REUSED FOR NEW BRANCH PIPE ROUTING. CONTRACTOR MAY CHOOSE TO DEMO EXISTING CHASE AND REBUILD PIPE CHASE WITH SHEET-METAL. EITHER WAY, PAINT COVER TO MATCH WALL COLOR AFTER INSTALLATION IS COMPLETE.
- 2 ALL PIPING IS NEW ROUTED WITHIN CEILING CAVITY. INSTALL A SET OF SHUT-OFF VALVE (FULL PORT BALL-VALVE) AT SHOWN MAIN PIPE BRANCH CONNECTION. INSTALL MAIN LINE SHUT OFF VALVES BETWEEN EAST AND WEST WING PIPING. THESE VALVES ARE NORMALLY CLOSED AND ONLY USED DURING SERVICE OR LOW LOAD SEASONS.
- 3 NEW 4" CHILLED / HOT WATER PIPING DOWN TO MECHANICAL ROOM.

UNIT VENTILATOR (UV) SCHEDULE (4-PIPE CHILLED / HOT WATER SYSTEM)


UNIT TAG	UV-A	UV-B	UV-C
MANUFACTURER	DAIKIN	DAIKIN	DAIKIN
CABINET STYLE	UNIT VENTILATOR	UNIT VENTILATOR	UNIT VENTILATOR
MODEL TYPE	FACE & BYPASS, REHEAT	FACE & BYPASS, REHEAT	FACE & BYPASS, REHEAT
MOUNTING	FLOOR	FLOOR	FLOOR
RETURN AIR LOCATION	LOW FRONT	LOW FRONT	LOW FRONT
OUTLET LOCATION	TOP GRILLED DISCHARGE	TOP GRILLED DISCHARGE	TOP GRILLED DISCHARGE
OUTSIDE AIR LOCATION	BACK OF UNIT	BACK OF UNIT	BACK OF UNIT
OUTSIDE AIR DAMPER	MOTORIZED OPEN/CLOSED	MOTORIZED OPEN/CLOSED	MOTORIZED OPEN/CLOSED
OUTSIDE AIR POSITION	SET TO 0A CFM WHEN OPEN	SET TO 0A CFM WHEN OPEN	SET TO 0A CFM WHEN OPEN
OUTSIDE AIR DAMPER	RIGHT DOUBLE WALL INSULATED	RIGHT DOUBLE WALL INSULATED	RIGHT DOUBLE WALL INSULATED
CABINET INSULATION	INTERNAL LINED	INTERNAL LINED	INTERNAL LINED
HEATING / COOLING	CHILLED / HOT WATER	CHILLED / HOT WATER	CHILLED / HOT WATER
COOLING COIL	4 ROWS FACE / BYPASS	4 ROWS FACE / BYPASS	4 ROWS FACE / BYPASS
HEATING COIL	2 ROWS	2 ROWS	2 ROWS
COIL POSITIONS	COOLING COIL BEFORE HEATING	COOLING COIL BEFORE HEATING	COOLING COIL BEFORE HEATING
ELECTRICAL	115 / 1 PHASE	115 / 1 PHASE	115 / 1 PHASE
CONDENSATE DRAIN	7/8" CONNECTION	7/8" CONNECTION	7/8" CONNECTION
PIPE CONNECTIONS	REVIEW PLANS / SITE VERIFY	REVIEW PLANS / SITE VERIFY	REVIEW PLANS / SITE VERIFY
MOTOR SPEED	1/3 HP ECM MOTOR	1/3 HP ECM MOTOR	1/3 HP ECM MOTOR
VENTILATING	MANUAL WITH DRAIN PLUG	MANUAL WITH DRAIN PLUG	MANUAL WITH DRAIN PLUG
DRAIN PAN	STAINLESS STEEL	STAINLESS STEEL	STAINLESS STEEL
FILTERS	1" THROW-AWAY	1" THROW-AWAY	1" THROW-AWAY
AIR PURIFICATION	GPS AIR PURIFICATION NOTE 3	GPS AIR PURIFICATION NOTE 3	GPS AIR PURIFICATION NOTE 3
DISCONNECT SWITCH	INTERNAL DISCONNECT	INTERNAL DISCONNECT	INTERNAL DISCONNECT
UNIT SIZE	1250 CFM	1000 CFM	750 CFM
COOLING EDB TEMP	80.00	80.00	80.00
COOLING EWB TEMP	57.00	57.00	57.00
CHILLED WATER BWT	45.00	45.00	45.00
TOTAL COOLING MBH	43.3	35.8	24.5
COOLING GENS MBH	28.7	23.3	15.3
COOLING WATER FLOW IN GPM	9	7.5	6
HEATING EDB TEMP	60.00	60.00	60.00
HEATING EWB TEMP	160	160	160
HEATING CAPACITY	26.18	26.18	26.18
HEATING WATER FLOW	5	5	5
MCA	15	15	15
FUSE SIZE	15	15	15
UNIT DIMENSIONS	86 X 22 X 30	74 X 22 X 30	62 X 22 X 30

- Notes:
1. UL LISTED / AHRI CERTIFIED CHILLED WATER
 2. INSULATED UNIT BACK WITH BUILT IN PIPE TUNNEL
 3. INSTALL GPS AIR PURIFICATION ON DISCHARGE AIR TIED TO EQUIPMENT OPERATION
 4. DRAIN ROUTED TO EXTERIOR AND DISCHARGE AT GRADE
 5. UNIT WITH REMOTE THERMOSTAT AND INTERNAL BACKUP CONTROLLER
 6. UNIT WITH CHILLED AND HOT WATER HOSE KITS
 7. CONTROL CONTRACTOR PROVIDE AND INSTALL BELIMO CONTROL VALVES
 8. CHILLED WATER WITH 20% GLYCOL

1 OVERALL MECHANICAL NEW PLAN
SCALE: 1/16"=1'-0"



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY ACE
DATE 11/30/2020
SET CLIENT REVIEW



REVISION DESCRIPTION

Δ DDMM/YYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200021

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO BUILDING OFFICIALS AND CONTRACTORS WITH THE INTENT OF CONSTRUCTING NAMED PROJECT IS PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO THE DESIGN INTENT ESTABLISHED BY THE COMPLETE SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE SOLE PROPERTY OF DECO ARCHITECTS UNLESS EXPRESSLY TRANSFERRED THROUGH WRITTEN CONTRACT.

MECHANICAL NEW PLAN

M-2.00

ELECTRICAL

ELECTRICAL LEGEND - LIGHTING

SYMBOL	DESCRIPTION
	CEILING OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	CEILING OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	CEILING OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	REMOTE HEAD, CONTROLLED BY EXIT LIGHT.
	CEILING OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	WALL OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	WALL MOUNTED EMERGENCY LIGHT AS SCHEDULED.
	WALL OUTLET AND LIGHTING FIXTURE AS SCHEDULED.
	SYMBOL INDICATES FIXTURE TYPE WHEN SHOWN ON LIGHTING PLANS ADJACENT TO FIXTURE SYMBOL. REFER TO LIGHTING FIXTURE SCHEDULE FOR FIXTURE REQUIREMENTS.
	OUTLET BOX AND 20-AMP, SINGLE-POLE SWITCH. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. SUB-TEXT INDICATES CIRCUIT SWITCHED.
	OUTLET BOX AND 20-AMP, THREE-WAY SWITCH. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. SUB-TEXT INDICATES CIRCUIT SWITCHED.
	OUTLET BOX AND 20-AMP, FOUR-WAY SWITCH. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. SUB-TEXT INDICATES CIRCUIT SWITCHED.
	OUTLET BOX AND 20-AMP, SINGLE-POLE DIMMER SWITCH. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. SUB-TEXT INDICATES CIRCUIT SWITCHED.
	OUTLET BOX AND 20-AMP, THREE-WAY DIMMER SWITCH. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. SUB-TEXT INDICATES CIRCUIT SWITCHED.
	OUTLET BOX AND 20-AMP, COMBINATION SWITCH AND OCCUPANCY SENSOR. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. OTHER TEXT INDICATES SWITCH CONFIGURATION AND CIRCUIT SWITCHED AS OTHER NON-OCCUPANCY SENSOR SWITCHES.
	OUTLET BOX AND 10-AMP, COMBINATION SWITCH AND LOW-VOLTAGE (0-10V) DIMMER. MOUNT AT 46 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE. LOCATE WITHIN 12 INCHES OF STRIKE SIDE OF DOOR, UNLESS NOTED OTHERWISE. OTHER TEXT INDICATES SWITCH CONFIGURATION AND CIRCUIT SWITCHED AS OTHER NON-DIMMER SWITCHES.
	CEILING-MOUNT OCCUPANCY SENSOR. THE LETTER(S) DESIGNATION ADJACENT TO THE SYMBOL (IF SHOWN) INDICATE SWITCHING ZONES TO BE CONTROLLED BY THE SENSOR. IF A LETTER DESIGNATION IS NOT SHOWN, THE SENSOR SHALL CONTROL ALL LIGHTING FIXTURES WITHIN THE ROOM.
	WALL-MOUNT OCCUPANCY SENSOR. THE LETTER(S) DESIGNATION ADJACENT TO THE SYMBOL (IF SHOWN) INDICATE SWITCHING ZONES TO BE CONTROLLED BY THE SENSOR. IF A LETTER DESIGNATION IS NOT SHOWN, THE SENSOR SHALL CONTROL ALL LIGHTING FIXTURES WITHIN THE ROOM.

ELECTRICAL LEGEND - TELCOM

SYMBOL	DESCRIPTION
	VOICE/DATA OUTLET. MOUNT OUTLET BOX AT 18 INCHES A.F.F. TO CENTER (EVEN WITH ADJACENT RECEPTACLE IF PRESENT) OR 8 INCHES ABOVE COUNTER OR COUNTER BACKSPASH TO CENTER, UNLESS NOTED OTHERWISE. PROVIDE 1 INCH CONDUIT WITH PULLSTRING FROM OUTLET BOX TO NEAREST ACCESSIBLE CEILING CAVITY. BUSH CONDUIT ENDS. OUTLET BOX SHALL BE 4 INCH SQUARE BY 2-3/4 INCH DEEP WITH A SINGLE GANG PLASTER RING, UNLESS NOTED OTHERWISE. "V" TEXT ADJACENT TO SYMBOL DENOTES WALL PHONE LOCATION (MOUNT AT 56 INCHES A.F.F. TO CENTER). WHERE SHOWN ADJACENT TO A POWER RECEPTACLE, INSTALL OUTLET AT SAME HEIGHT, WITHIN 6 INCHES OF RECEPTACLE, UNLESS OTHERWISE NOTED.
	VIDEO MONITOR OUTLET. MOUNT OUTLET BOX AT 18 INCHES A.F.F. TO CENTER (EVEN WITH ADJACENT RECEPTACLE). PROVIDE 1 INCH CONDUIT FROM OUTLET BOX TO NEAREST ACCESSIBLE ATTIC SPACE. BUSH CONDUIT ENDS. OUTLET BOX SHALL BE 4 INCH SQUARE BY 2-3/4 INCH DEEP WITH A SINGLE GANG PLASTER RING, UNLESS NOTED OTHERWISE.
	CEILING MOUNTED COMMUNICATIONS OUTLET BOX FOR WIRELESS ACCESS POINT. OUTLET BOX SHALL BE FOUR INCHES WITH A SINGLE GANG PLASTER RING.

ELECTRICAL LEGEND - POWER

SYMBOL	DESCRIPTION
	WALL OUTLET WITH 20A, 125V DUPLEX RECEPTACLE. MOUNT 18 INCHES ABOVE FINISHED FLOOR TO TO CENTER, UNLESS NOTED OTHERWISE.
	WALL OUTLET WITH 20A, 125V DUPLEX RECEPTACLE. MOUNT 48 INCHES ABOVE FINISHED FLOOR TO TO CENTER, OR 8 INCHES ABOVE COUNTER OR COUNTER BACKSPASH TO CENTER, UNLESS NOTED OTHERWISE.
	CEILING MOUNTED OUTLET WITH 20A, 125V DUPLEX RECEPTACLE.
	WALL OUTLET WITH 20A, 125V DOUBLE-DUPLEX RECEPTACLE. MOUNT 18 INCHES ABOVE FINISHED FLOOR TO CENTER, UNLESS NOTED OTHERWISE.
	WALL OUTLET WITH 20A, 125V DOUBLE-DUPLEX RECEPTACLE. MOUNT 48 INCHES ABOVE FINISHED FLOOR TO TO CENTER, OR 8 INCHES ABOVE COUNTER OR COUNTER BACKSPASH TO CENTER, UNLESS NOTED OTHERWISE.
	WALL OUTLET WITH SIMPLEX RECEPTACLE AS NOTED ON POWER PLANS.
	FLOOR OUTLET WITH DUPLEX RECEPTACLE AND 2 PORT DATA OUTLET.
	FLOOR OUTLET WITH DOUBLE-DUPLEX RECEPTACLE AND 2 PORT DATA OUTLET.
GFCI	SYMBOL INDICATES GROUND FAULT CIRCUIT INTERRUPTER TYPE RECEPTACLE WHEN SHOWN ADJACENT TO RECEPTACLE SYMBOL ON PLANS.
WP	SYMBOL INDICATES WESTHER-PROOF WHILE-IN-USE TYPE ENCLOSURE WHEN SHOWN ADJACENT TO RECEPTACLE SYMBOL ON PLANS.
1,3,5,...	NUMBER TEXT INDICATES CIRCUIT NUMBERS WHEN SHOWN ADJACENT TO SYMBOLS ON PLAN.
a,b,c,...	LOWER-CASE LETTER TEXT INDICATES CIRCUIT SWITCHING ARRANGEMENT WHEN SHOWN WITHIN OR ADJACENT TO SYMBOLS ON PLAN.
+48"	NUMBER TEXT INDICATES MOUNTING HEIGHT ABOVE FINISHED FLOOR TO CENTER OF OUTLET BOX WHEN SHOWN ADJACENT TO SYMBOLS ON PLAN.
Ⓜ	WALL-MOUNT JUNCTION BOX AS NOTED ON PLANS.
Ⓢ	CEILING-MOUNT JUNCTION BOX AS NOTED ON PLANS.
Ⓜ	JUNCTION BOX WITH PHOTO EYE.
Ⓜ	WALL-MOUNT PUSH BUTTON FOR ADA DOORS. MOUNTED AT ADA REQUIRED HEIGHTS.
30A/3 NEMA 3R	NON-FUSIBLE DISCONNECT SWITCH. TEXT INDICATES AMP AND ENCLOSURE RATINGS.
30A/3 NEMA 3R	FUSIBLE DISCONNECT SWITCH. TEXT INDICATES AMP AND ENCLOSURE RATINGS.
PHASE CONDUCTOR	
GROUND NEUTRAL	
LP1-1,3,5	HOME RUN TO PANEL. NUMBER OF ARROW HEADS INDICATES NUMBER OF CIRCUITS. PREFIX INDICATES PANEL NOMENCLATURE. NUMBERS INDICATE CIRCUIT NUMBERS.

FIRE ALARM LEGEND

DESCRIPTION	MOUNTING	QTY
PHOTO ELECTRIC SMOKE DETECTOR	REPLACE CURRENT	11
AUDIO VISUAL NOTIFICATION DEVICE	REPLACE CURRENT	21
VISUAL NOTIFICATION DEVICE	REPLACE CURRENT	4
HEAT DETECTOR ROR AND FIXED	REPLACE CURRENT	1
MANUAL PULL STATION	REPLACE CURRENT	13
ADDRESSABLE FIRE ALARM CONTROL PANEL	REPLACE CURRENT	1
NOTIFICATION DEVICE POWER SUPPLY	REPLACE CURRENT	1
ANNUNCIATOR PANEL	REPLACE CURRENT	1
NEW LOCATION - AUDIO VISUAL NOTIFICATION DEVICE	SINGLE GANG 80-96" TO BOTTOM AFF	3
NEW LOCATION - VISUAL NOTIFICATION DEVICE	SINGLE GANG 80-96" TO BOTTOM AFF	37
NEW LOCATION - MANUAL PULL STATION	SINGLE GANG 82" TO BOTTOM AFF	1
SPRINKLER WATERFLOW MONITOR	REPLACE CURRENT	1
SPRINKLER TAMPER VALVE MONITOR	REPLACE CURRENT	1

1. Existing fire alarm device location. Remove device and wiring. Install blank cover plate.

PA SYSTEM LEGEND

DESCRIPTION	MOUNTING	QTY
INTERCOM HEADEND - REPLACE WITH QUANTITY OF ZONES AND AMPLIFIERS TO ACCOMMODATE SYSTEM. MINIMUM ROOM POINTS WITH GLASSROOM CALL-IN. INTERCOM SYSTEM PHONE - PERFORM FUNCTION OF NEW INTERCOM SYSTEM	RACK MOUNT	1
DOOR PHONE - CALL IN STATION TO RING OFFICE INTERCOM PHONE.	DESK MOUNT	1
DOOR PHONE - CALL IN STATION TO RING OFFICE INTERCOM PHONE.	SURFACE MOUNT 44" TO BOTTOM AFF	1
EXISTING INTERCOM SPEAKER. REUSE SPEAKER AND EXISTING CABLING.	CEILING	59
CLASSROOM CALL IN BUTTON - NEW LOCATION	SINGLE GANG	31
VANDAL RESISTANT SURFACE MOUNT SPEAKER - NEW LOCATION	SURFACE	2
2X2 LAY-IN CEILING SPEAKER - NEW LOCATION	CEILING	2
OUTDOOR HORN - NEW LOCATION	SURFACE	3

ACCESS CONTROL LEGEND

DESCRIPTION	MOUNTING	QTY
WIRELESS LOCKSET	REPLACE CURRENT LOCKSET	36
PANEL INTERFACE MODULE	SURFACE MOUNT ABOVE CEILING	11
CARD READER	SINGLE GANG 44" TO BOTTOM AFF	11
ELECTRONIC DOOR HARDWARE	NA	11
REQUEST TO EXIT DEVICE	SINGLE GANG ABOVE DOOR HEADER	11
DOOR POSITION SWITCH	3/4" HOLE IN FRAME AND DOOR	21
DOOR POWER SUPPLY	SURFACE MOUNT 48" TO BOTTOM AFF	2
ACCESS CONTROL HEADEND	SURFACE MOUNT 48" TO BOTTOM AFF	1

CCTV LEGEND


DESCRIPTION	MOUNTING	QTY
OUTDOOR BULLET CAMERA - 5MP	SURFACE MOUNT BOX INCLUDED CEILING MOUNT	13
INDOOR DOME CAMERA - 5MP	CEILING MOUNT	28
FISHEYE CAMERA - 12MP	CEILING MOUNT	1
NVR SERVER - HDD AND CHANNELS TO ACCOMADATE ALL CAMERAS	RACK MOUNT	1

GENERAL NOTES:

- ALL WORK SHALL BE DONE BY A LICENSED CONTRACTOR.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR JOBSITE SAFETY, INCLUDING REQUIREMENTS OF AUTHORITIES HAVING JURISDICTION.
- ALL CONSTRUCTION DEBRIS SHALL BE DISPOSED OF BY THE CONTRACTOR, UNLESS NOTES OTHERWISE.
- THERE SHALL BE NOTHING ABANDONED IN PLACE, UNLESS SPECIFICALLY IDENTIFIED AS SUCH.
- ALL WORK SHALL COMPLY WITH THE REQUIREMENTS OF THE CONTRACT DOCUMENTS, INCLUDING ADDENDA, AND APPLICABLE CODES AND STANDARDS.
- ALL TRADES SHALL COORDINATE THE ROUTING AND INSTALLATION OF HIS WORK WITH THAT OF ALL OTHER TRADES THROUGH THE GENERAL CONTRACTOR.
- PROVIDE ALL EQUIPMENT, MATERIAL, LABOR, SUPERVISION, COST, AND SERVICES REQUIRED TO INSTALL COMPLETE AND WORKING SYSTEMS, INCLUDING ALL ITEMS AND APPURTENANCES NECESSARY, REASONABLE, INCIDENTAL, OR CUSTOMARILY INCLUDED, EVEN THOUGH EACH AND EVERY ITEM IS NOT SPECIFIED OR SHOWN.




DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE THAT ALL PERMITS AND APPROVALS ARE OBTAINED PRIOR TO COMMENCING WORK.

BY	KEL
DATE	01/07/2021
SET	CLIENT REVIEW



REVISION	DESCRIPTION
1	DDMMYYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020

515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO BUILDING OFFICIALS AND CONTRACTORS WITH THE INTENT OF CONSTRUCTING NAMED PROJECT IS PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO THE DESIGN INTENT ESTABLISHED BY THE COMPLETE SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE SOLE PROPERTY OF DECO ARCHITECTS UNLESS EXPRESSLY TRANSFERRED THROUGH WRITTEN CONTRACT.

ELECTRICAL
LEGENDS

E-0.01


ELECTRICAL



1 OVERALL FLOORPLAN - CCTV AND ACCESS CONTROL
SCALE: 1/16"=1'-0"



DESIGN PROFESSIONAL




PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY KEL

DATE 11/30/2020

SET CLIENT REVIEW



REVISION	DESCRIPTION
A	DDMMYYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

ELECTRICAL
ENLARGED AREA C & D


E-1.01

ELECTRICAL




ELECTRICAL DEMO NOTES:


- 1 DISCONNECT ELECTRICAL CIRCUIT FOR EXISTING UNIT VENTILATOR, LEAVE CIRCUIT IN PLACE FOR NEW UNIT VENTILATOR TO BE INSTALLED IN SAME SPACE. COORDINATE WITH MECHANICAL CONTRACTOR FOR ANY ADDITIONAL REQUIREMENTS FOR REMOVING EXISTING UNIT VENTILATORS. FIELD VERIFY CONDITION OF CIRCUITRY AND DISCONNECTS.
- 2 DISCONNECT AND DEMOLISH COMPLETELY ELECTRICAL CIRCUITS FOR EXISTING BELOW CEILING FAN COIL UNIT, COORDINATE WITH MECHANICAL CONTRACTOR FOR ANY ADDITIONAL REQUIREMENTS FOR REMOVAL OF EXISTING BELOW CEILING FAN COIL UNITS.
- 3 DISCONNECT AND REMOVE EXISTING BATHROOM LIGHT FIXTURES. FIELD VERIFY EXISTING SWITCH LEG CAN BE REWORKED TO ACCOMMODATE NEW LIGHTING LAY-OUT.
- 4 ELECTRICAL CONTRACTOR TO COORDINATE WITH GENERAL CONTRACTOR FOR ANY DEMO WORK TO BE DONE IN THIS AREA TO ACCOMMODATE THE NEW FLOOR PLAN. FIELD VERIFY EXISTING CIRCUITS CAN BE REWORKED TO ACCOMMODATE NEW FLOOR PLAN.



1 OVERALL FLOORPLAN - ELECTRICAL DEMO PLAN
SCALE: 1/16"=1'-0"




DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY KEL
DATE 11/30/2020
SET CLIENT REVIEW



REVISION	DESCRIPTION
1	DDMMYYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE **COMPLETE**
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

ELECTRICAL DEMO
PLAN C & D

E-1.02


ELECTRICAL



1 OVERALL FLOORPLAN - ELECTRICAL POWER AND LIGHTING PLAN
SCALE: 1/16"=1'-0"



DESIGN PROFESSIONAL



PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY KEL

DATE 01/07/2021

SET CLIENT REVIEW



REVISION DESCRIPTION

Δ DDMMYYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821


DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

ELECTRICAL POWER
AND LIGHTING
AREA C & D

E-1.03


ELECTRICAL



1 ENLARGED FLOOR PLAN - TOILET @ ENTRY - DEMO

SCALE: 1/4"=1'-0"


0 2' 4' 8'



2 ENLARGED FLOOR PLAN - TOILET @ ENTRY - NEW WORK

SCALE: 1/4"=1'-0"

0 2' 4' 8'



PRELIMINARY:
NOT FOR
CONSTRUCTION

DESIGN PROFESSIONAL

PLAN REVIEWER

IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY

ACE

DATE

01/07/2021

SET

CLIENT REVIEW

DD

CD

REVISION

DESCRIPTION

Δ

DDMM/YYYY

REVISION DESCRIPTION

DECO

ARCHITECTS

Somerset, Kentucky
(606)687 - 9233
www.decoarchitects.co

TODD COUNTY MIDDLE SCHOOL

RENOVATION 2020

515 W MAIN ST

ELKTON, KENTUCKY 42220

20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.


COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE **COMPLETE**
SET OF CONSTRUCTION DOCUMENTS.

THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.


PLUMBING
ENLARGED FLOOR PLAN

P-1.01


PLUMBING




3 ENLARGED FLOOR PLAN - TOILET @ GYM - DEMO
SCALE: 1/4"=1'-0"




4 ENLARGED FLOOR PLAN - TOILET @ GYM - NEW WORK
SCALE: 1/4"=1'-0"



1 ENLARGED FLOOR PLAN - TOILET @ ENTRY - DEMO
SCALE: 1/4"=1'-0"




2 ENLARGED FLOOR PLAN - TOILET @ ENTRY - NEW WORK
SCALE: 1/4"=1'-0"



KEY PLAN
NOT TO SCALE




DESIGN PROFESSIONAL



PLAN REVIEWER
IF NO STAMP IS PRESENT, PLAN REVIEW MAY BE PENDING.
IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO
ENSURE THAT ALL PERMITS AND APPROVALS ARE
OBTAINED PRIOR TO COMMENCING WORK.

BY ACE
DATE 01/07/2021
SET CLIENT REVIEW



REVISION	DESCRIPTION
1	DDMM/YYYY REVISION DESCRIPTION



TODD COUNTY MIDDLE SCHOOL
RENOVATION 2020
515 W MAIN ST
ELKTON, KENTUCKY 42220
20200821

DO NOT REMOVE ANY ELEMENT OF THESE DOCUMENTS
FROM THE DRAWING BORDER.
COPYING THESE DOCUMENTS FOR DISTRIBUTION TO
BUILDING OFFICIALS AND CONTRACTORS WITH THE
INTENT OF CONSTRUCTING NAMED PROJECT IS
PERMITTED, PROVIDED THAT EACH PARTY IS ISSUED A
FULL SET OF DOCUMENTS. THIS ARCHITECT IS NOT
RESPONSIBLE FOR WORK THAT DOES NOT ADHERE TO
THE DESIGN INTENT ESTABLISHED BY THE COMPLETE
SET OF CONSTRUCTION DOCUMENTS.
THIS WORK IS PROTECTED UNDER THE UNITED STATES
ARCHITECTURAL WORKS COPYRIGHT PROTECTION ACT
OF 1990. ALL ORIGINAL WORK HEREIN REMAINS THE
SOLE PROPERTY OF DECO ARCHITECTS UNLESS
EXPRESSLY TRANSFERRED THROUGH WRITTEN
CONTRACT.

PLUMBING
ENLARGED FLOOR PLAN

P-1.02

PLUMBING