

## **ADDENDUM #1**

**PROJECT**                      **Partial Reroofing & Roof Repairs 2022**  
**Pembroke Elementary School – Pembroke, KY**  
**JKS # 2021058      BG # 22-338**

**Owner:**                      **Christian County Board of Education**  
**PO Box 609 – 200 Glass Avenue**  
**Hopkinsville, KY 42240**

**ISSUE DATE:**              **May 2, 2022**

**ISSUED BY:**              **JKS Architecture**  
**402 Liberty Street**  
**Hopkinsville, KY 42240**  
**Phone: 270-885-2296**

The following items modify the contract documents as indicated:

Item # 1:      Drawing Sheets A-3.0, A-3.1 & A-3.2. Specification Section  
075500.

Attachment of Reroof system shall be:  
Base Sheet – Nailed  
Insulation – Hot Asphalt  
Base Ply – Hot Asphalt  
Cap Sheet – Cold Applied Mastic  
Base Ply Flashing – Hot Asphalt  
Cap Ply Flashing – Cold Applied Mastic

Item # 2:      Drawing Sheet A-3.0, A-3.1 and A-3.2 Specification Section  
075630.

Flashing for restoration areas shall be one ply mineral cap flashing  
in lieu of two ply.

**END OF ADDENDUM # 1**