

**AEM Shutdown with ENERGY STAR
Weekly Performance Report Monday, August 12th, 2024, through Sunday,
August 18th, 2024**

Chris Baker,

This week the school district used over 11,000 kWh less energy compared to last year, congratulations!

The standouts for this week are:

- 1) Congratulations to Simon Kenton High School for a 27% energy reduction compared to last year! That's over \$1,000 in savings!
- 2) Kenton Elementary School had a 47% increase in energy usage compared to last year, resulting in a cost of almost \$700. Starting Tuesday, there seems to have been an increase in energy use during unoccupied hours.



This is the first week of your school year. This week, energy usage was **\$1,088** below last year. Please take a look below to review your school's performance with saving opportunities highlighted. Thank you for all your efforts.



Your AEM Intern Team,

Keira and Nigelle


School	Previous Use (kWh)	Current Use (kWh)	kWh Savings (+ is reduction - is increase)	% of kWh Savings	Cost Savings
Caywood Elementary	12,443	10,598	1,845	15%	\$185
Dixie Heights High	35,574	40,354	-4,780	-13%	-\$478
Ft Wright Elementary	10,561	11,196	-635	-6%	-\$64
Kenton Elementary	14,796	21,728	-6,932	-47%	-\$693
R C Hinsdale Elementary	14,973	12,326	2,647	18%	\$265
River Ridge Elementary	22,715	23,400	-685	-3%	-\$69
Ryland Hights Elementary	9,974	9,506	468	5%	\$47
Scott High	29,717	40,032	-10,315	-35%	-\$1,032
Simon Kenton High	56,317	41,257	15,060	27%	\$1,506
Summit View Campus	43,137	33,564	9,573	22%	\$957
Taylor Mill Elementary	15,717	12,199	3,518	22%	\$352
Twenhofel Middle	16,343	16,626	-283	-2%	-\$28
Whites Tower Elementary	8,235	9,539	-1,304	-16%	-\$130
Woodland Middle	13,232	10,528	2,704	20%	\$270
Total	303,734	292,853	10,881	3.72%	\$1,088

Please note: Dixie Heights is missing IDR data for the entire weekend, while Whites Tower is missing data from Saturday. The Previous Use data only includes days with current usage reported and may not match the reported total usage in the graphs.







R C Hinsdale Elementary School (62,571 sqft)




River Ridge Elementary School (138,800 sqft)




Ryland Heights Elementary School (66,906 sqft)



Scott High School (250,007 sqft)



Simon Kenton High School (214,252 sqft)




Previous
Mon. 08/14/2023 - Sun.
08/20/2023
kWh: 56,317
Low: 55F, High: 93F

Current vs Previous: -15,060 kWh for a cost reduction of \$1,506.00
Cost is based on \$0.10/kWh

Current
Mon. 08/12/2024 - Sun.
08/18/2024
kWh: 41,257
Low: 55F, High: 89F

Summit View Campus (211,637 sqft)




Previous
Mon. 08/14/2023 - Sun.
08/20/2023
kWh: 43,137
Low: 55F, High: 93F

Current vs Previous: -9,573 kWh for a cost reduction of \$957.30
Cost is based on \$0.10/kWh

Current
Mon. 08/12/2024 - Sun.
08/18/2024
kWh: 33,564
Low: 55F, High: 89F

Taylor Mill Elementary School (74,291 sqft)



Twenhofel Middle School (112,175 sqft)

