

PROJECT: 5056-01 Trans District Sup Fac 5056-01 DATE: 12/4/2024

VISIT NAME: Construction Progress Site Visit REPORT NO: 029

AUTHOR: David Vaught STATUS: Final

VISIT DETAILS

WEATHER: Mostly Cloudy High in the upper 30's START TIME: 11:00 AM END TIME: 2:00 PM

GENERAL COMMENTS: A construction progress site visit was conducted on December 4, 2024. The following items were noted.

| PARTICIPANT NAME | COMPANY | TITLE | EMAIL |
|------------------|---------|-----------------|--------------------|
| David Vaught | GRW | Project Manager | DVaught@grwinc.com |

OBSERVATIONS

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------------------------------------|
| 029-001 | Roll over vehicle washer installation in progress. Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab. Paint installation in progress. | |  |
| | SPACE: 143 - AUTOMATIC WASH BAY | SUBJECT: 12/4/24 at 12:22 PM | |
| | CATEGORY: Joint Sealants / Painting / Roll over vehicle washer | REFERENCE: 079200 / 099123 / 115000 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-002 | Roll over vehicle washer installation in progress. Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab. Paint installation in progress. | |  |
| | SPACE: | 143 - AUTOMATIC WASH BAY | SUBJECT: 12/4/24 at 12:23 PM |
| | CATEGORY: | Joint Sealants / Painting / Roll over vehicle washer | REFERENCE: 079200 / 099123 / 115000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|---------------------|
| 029-003 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> | |  | |
| | SPACE: | 145 - CIRCULATION | SUBJECT: | 12/4/24 at 12:23 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: | 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|---------------------|
| 029-004 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> | |  | |
| | SPACE: | 145 - CIRCULATION | SUBJECT: | 12/4/24 at 12:23 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: | 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|
| 029-005 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> | |  |
| | SPACE: | 142 - TIRE STORAGE | SUBJECT: 12/4/24 at 12:24 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|-----------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-006 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Unit heater installation in progress.</p> | |  |
| SPACE: | 142 - TIRE STORAGE | SUBJECT: | 12/4/24 at 12:24 PM |
| CATEGORY: | Joint Sealants / Painting / Ductwork | REFERENCE: | 079200 / 099123 / 233113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|---------------------|
| 029-007 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> | |  | |
| | SPACE: | 144 - STORAGE ROOM | SUBJECT: | 12/4/24 at 12:24 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: | 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|
| 029-008 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Overhead coiling door installation in progress.</p> | |  |
| | SPACE: | 144 - STORAGE ROOM | SUBJECT: 12/4/24 at 12:25 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|---------------------|
| 029-009 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Ceiling paint installation complete.</p> | |  | |
| | SPACE: | 146 - CIRCULATION | SUBJECT: | 12/4/24 at 12:25 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: | 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|---------------------|
| 029-010 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Ceiling paint installation complete.</p> <p>Paint exposed ductwork / conduit.</p> | |  | |
| | SPACE: | 146 - CIRCULATION | SUBJECT: | 12/4/24 at 12:25 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: | 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-011 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Ceiling paint installation complete.</p> <p>Paint exposed ductwork / conduit.</p> | |  | |
| | SPACE: | 147 - POL STORAGE ROOM | SUBJECT: | 12/4/24 at 12:25 PM |
| | CATEGORY: | Joint Sealants / Painting / Vehicular Fluids Piping | REFERENCE: | 079200 / 099123 / 231113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|-------------------------------------------------------------------------------------|
| 029-012 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>POL storage tanks are on site. Installation in progress.</p> | |  |
| | <p>SPACE: 147 - POL STORAGE ROOM</p> | <p>SUBJECT: 12/4/24 at 12:26 PM</p> | |
| | <p>CATEGORY: Joint Sealants / Painting / Vehicular Fluids Piping</p> | <p>REFERENCE: 079200 / 099123 / 231113</p> | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-013 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>POL storage tanks are on site. Installation in progress.</p> | |  | |
| | SPACE: | 147 - POL STORAGE ROOM | SUBJECT: | 12/4/24 at 12:26 PM |
| | CATEGORY: | Joint Sealants / Painting / Vehicular Fluids Piping | REFERENCE: | 079200 / 099123 / 231113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|-------------------------------------------------------------------------------------|
| 029-014 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Ductwork installation in progress. Provide duct flange at wall penetration. Paint ductwork.</p> | |  |
| | SPACE: | 149 - BATTERY STORAGE / CHARGING | SUBJECT: 12/4/24 at 12:26 PM |
| | CATEGORY: | Joint Sealants / Painting / Ductwork | REFERENCE: 079200 / 099123 / 233113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|-------------------------------------------------------------------------------------|
| 029-015 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> | |  |
| | SPACE: | 150 - FLAMMABLE STORAGE AREA | SUBJECT: 12/4/24 at 12:27 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------|-------------------------------------------------------------------------------------|
| 029-016 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Electrical panel installation in progress.</p> | |  |
| | SPACE: | 151 - ELECTRICAL CLOSET | SUBJECT: 12/4/24 at 12:27 PM |
| | CATEGORY: | Joint Sealants / Painting / Electrical | REFERENCE: 079200 / 099123 / 260000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-017 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduit</p> | |  | |
| | SPACE: | 152 - COMM. CLOSET | SUBJECT: | 12/4/24 at 12:27 PM |
| | CATEGORY: | Joint Sealants / Painting / Electrical | REFERENCE: | 079200 / 099123 / 260000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|-------------------------------------------------------------------------------------|
| 029-018 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> | |  |
| | SPACE: | 153 - END OF BAY STORAGE | SUBJECT: 12/4/24 at 12:27 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: 079200 / 099123 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------|---------------------------------|---------------------------------------------------------------------------------------|
| 029-019 | Plumbing fixtures and equipment currently stored on site. | |  |
| | SPACE: | 153 - END OF BAY STORAGE | SUBJECT: 12/4/24 at 12:28 PM |
| | CATEGORY: | Plumbing Fixtures and Equipment | REFERENCE: 224200 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|---------------------|-----------|--------------------------------------|------------|--------------------------|--|--|
| 029-020 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">SPACE:</td> <td style="width: 45%;">153 - END OF BAY STORAGE</td> <td style="width: 25%;">SUBJECT:</td> <td style="width: 5%;">12/4/24 at 12:28 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Joint Sealants / Painting / Ductwork</td> <td>REFERENCE:</td> <td>079200 / 099123 / 233113</td> </tr> </table> | SPACE: | 153 - END OF BAY STORAGE | SUBJECT: | 12/4/24 at 12:28 PM | CATEGORY: | Joint Sealants / Painting / Ductwork | REFERENCE: | 079200 / 099123 / 233113 | | |
| SPACE: | 153 - END OF BAY STORAGE | SUBJECT: | 12/4/24 at 12:28 PM | | | | | | | | |
| CATEGORY: | Joint Sealants / Painting / Ductwork | REFERENCE: | 079200 / 099123 / 233113 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|
| 029-021 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Overhead coiling door installation in progress.</p> | |  |
| | SPACE: | 153 - END OF BAY STORAGE | SUBJECT: 12/4/24 at 12:28 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|
| 029-022 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Unit heater installation in progress.</p> | |  |
| | SPACE: | 141 - PARTS / INVENTORY | SUBJECT: 12/4/24 at 12:28 PM |
| | CATEGORY: | Joint Sealants / Painting / Unit Heaters | REFERENCE: 079200 / 099123 / 235533 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-023 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Overhead coiling door installation in progress.</p> | |  | |
| | SPACE: | 140 - PARTS STORAGE | SUBJECT: | 12/4/24 at 12:28 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: | 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-024 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Overhead coiling door installation in progress.</p> | |  | |
| | SPACE: | 140 - PARTS STORAGE | SUBJECT: | 12/4/24 at 12:29 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: | 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|
| 029-025 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Overhead coiling door installation in progress.</p> | |  |
| | SPACE: | 141 - PARTS / INVENTORY | SUBJECT: 12/4/24 at 12:29 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-026 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  |
| | SPACE: 131 - CIRCULATION | SUBJECT: 12/4/24 at 12:29 PM | |
| | CATEGORY: Joint Sealants / Painting / Plumbing | REFERENCE: 079200 / 099123 / 220000 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-027 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  | |
| | SPACE: | 138 - INSPECTION BAY 1 | SUBJECT: | 12/4/24 at 12:30 PM |
| | CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-028 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  | |
| | SPACE: | 139 - INSPECTION BAY 2 | SUBJECT: | 12/4/24 at 12:30 PM |
| | CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|---------------------|-----------|--------------------------------------|------------|--------------------------|--|--|
| 029-029 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">SPACE:</td> <td style="width: 30%;">133 - MAINTENANCE BAY 2</td> <td style="width: 25%;">SUBJECT:</td> <td style="width: 20%;">12/4/24 at 12:30 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Joint Sealants / Painting / Plumbing</td> <td>REFERENCE:</td> <td>079200 / 099123 / 220000</td> </tr> </table> | SPACE: | 133 - MAINTENANCE BAY 2 | SUBJECT: | 12/4/24 at 12:30 PM | CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 | | |
| SPACE: | 133 - MAINTENANCE BAY 2 | SUBJECT: | 12/4/24 at 12:30 PM | | | | | | | | |
| CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-030 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  | |
| | SPACE: | 131 - CIRCULATION | SUBJECT: | 12/4/24 at 12:31 PM |
| | CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|---------------------|-----------|--------------------------------------|------------|--------------------------|--|--|
| 029-031 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Plumbing piping installation is in progress.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">SPACE:</td> <td style="width: 30%;">132 - MAINTENANCE BAY 1</td> <td style="width: 25%;">SUBJECT:</td> <td style="width: 20%;">12/4/24 at 12:31 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Joint Sealants / Painting / Plumbing</td> <td>REFERENCE:</td> <td>079200 / 099123 / 220000</td> </tr> </table> | SPACE: | 132 - MAINTENANCE BAY 1 | SUBJECT: | 12/4/24 at 12:31 PM | CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 | | |
| SPACE: | 132 - MAINTENANCE BAY 1 | SUBJECT: | 12/4/24 at 12:31 PM | | | | | | | | |
| CATEGORY: | Joint Sealants / Painting / Plumbing | REFERENCE: | 079200 / 099123 / 220000 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-032 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | |
| | SPACE: | 109 - SHARED LOADING DOCK | SUBJECT: | 12/4/24 at 12:32 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 092900 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|---------------------|-----------|------------------------------------------|------------|--------------------------|--|--|
| 029-033 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">SPACE:</td> <td style="width: 35%;">109 - SHARED LOADING DOCK</td> <td style="width: 20%;">SUBJECT:</td> <td style="width: 25%;">12/4/24 at 12:32 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Joint Sealants / Gypsum Board / Painting</td> <td>REFERENCE:</td> <td>079200 / 092900 / 099123</td> </tr> </table> | SPACE: | 109 - SHARED LOADING DOCK | SUBJECT: | 12/4/24 at 12:32 PM | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 092900 / 099123 | | |
| SPACE: | 109 - SHARED LOADING DOCK | SUBJECT: | 12/4/24 at 12:32 PM | | | | | | | | |
| CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 092900 / 099123 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-034 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> <p>Freezer door installation in progress. Provide checker plate metal at perimeter of masonry opening to match checker plate metal on freezer door.</p> | |  | |
| | SPACE: | 118 - FREEZER STORAGE | SUBJECT: | 12/4/24 at 12:32 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 092900 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-035 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  |
| | SPACE: 110 - CIRCULATION | SUBJECT: 12/4/24 at 12:33 PM | |
| | CATEGORY: Joint Sealants / Gypsum Board / Painting | REFERENCE: 079200 / 092900 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-036 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: | 119 - DRIVERS BREAK ROOM | SUBJECT: 12/4/24 at 12:33 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-037 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: | 119 - DRIVERS BREAK ROOM | SUBJECT: 12/4/24 at 12:33 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------|---------------------|---------------------------------------------------------------------------------------|
| 029-038 | Ceramic tile installation in progress. | |  |
| | SPACE: | 121 - MALE RESTROOM | SUBJECT: 12/4/24 at 12:34 PM |
| | CATEGORY: | Ceramic Tiling | REFERENCE: 093013 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------|-----------------------|-------------------------------------------------------------------------------------|
| 029-039 | Ceramic tile installation in progress. | |  |
| | SPACE: | 120 - FEMALE RESTROOM | SUBJECT: 12/4/24 at 12:34 PM |
| | CATEGORY: | Ceramic Tiling | REFERENCE: 093013 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-040 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: | 119 - DRIVERS BREAK ROOM | SUBJECT: 12/4/24 at 12:35 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|
| 029-041 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduit.</p> | |  |
| | SPACE: | 115 - VENDER RECEIVING AREA | SUBJECT: 12/4/24 at 12:36 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-042 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduit.</p> <p>Overhead coiling door installation in progress.</p> | |  | |
| | SPACE: | 114 - SHARED LOADING DOCK | SUBJECT: | 12/4/24 at 12:36 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: | 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-043 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduit.</p> <p>Overhead coiling door installation in progress.</p> | |  | |
| | SPACE: | 114 - SHARED LOADING DOCK | SUBJECT: | 12/4/24 at 12:36 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: | 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------|------------------------|-------------------------------------------------------------------------------------|
| 029-044 | Food service equipment installation in progress. | |  |
| | SPACE: | 118 - FREEZER STORAGE | SUBJECT: 12/4/24 at 12:37 PM |
| | CATEGORY: | Food Service Equipment | REFERENCE: 114000 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------|------------------------|-------------------------------------------------------------------------------------|
| 029-045 | Food service equipment installation in progress. | |  |
| | SPACE: | 118 - FREEZER STORAGE | SUBJECT: 12/4/24 at 12:37 PM |
| | CATEGORY: | Food Service Equipment | REFERENCE: 114000 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------|------------------------|---------------------------------------------------------------------------------------|
| 029-046 | Food service equipment installation in progress. | |  |
| | SPACE: | 118 - FREEZER STORAGE | SUBJECT: 12/4/24 at 12:37 PM |
| | CATEGORY: | Food Service Equipment | REFERENCE: 114000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------|------------------------|-------------------------------------------------------------------------------------|
| 029-047 | Food service equipment installation in progress. | |  |
| | SPACE: | 118 - FREEZER STORAGE | SUBJECT: 12/4/24 at 12:37 PM |
| | CATEGORY: | Food Service Equipment | REFERENCE: 114000 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|--------------------------------------------------------------------------------------|
| 029-048 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduits</p> | |  |
| | SPACE: | 117 - DRY FOOD STORAGE | SUBJECT: 12/4/24 at 12:38 PM |
| | CATEGORY: | Joint Sealants / Painting | REFERENCE: 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|
| 029-049 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete. Paint exposed conduit.</p> <p>Overhead coiling door installation in progress.</p> | |  |
| | SPACE: | 117 - DRY FOOD STORAGE | SUBJECT: 12/4/24 at 12:39 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|
| 029-050 | Metal pan stair installation in progress. Pipe and tube rail installation in progress. Provide cane detection real at stair landing. | |  |
| | SPACE: | 111 - STAIR B | SUBJECT: 12/4/24 at 12:39 PM |
| | CATEGORY: | Metal Pan Stairs / Pipe and Tube Railings | REFERENCE: 055113 / 055213 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-051 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | |
| | SPACE: | 103 - CIRCULATION | SUBJECT: | 12/4/24 at 12:40 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-052 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: | 130 - MECHANIC BREAK ROOM | SUBJECT: 12/4/24 at 12:41 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|---------------------|-----------|------------------------------------------------|------------|--------------------------|--|--|
| 029-053 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">SPACE:</td> <td style="width: 30%;">129 - ADMIN. ASSISTANT OFFICE</td> <td style="width: 25%;">SUBJECT:</td> <td style="width: 20%;">12/4/24 at 12:41 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Joint Sealants / Acoustical Ceiling / Painting</td> <td>REFERENCE:</td> <td>079200 / 095113 / 099123</td> </tr> </table> | SPACE: | 129 - ADMIN. ASSISTANT OFFICE | SUBJECT: | 12/4/24 at 12:41 PM | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 | | |
| SPACE: | 129 - ADMIN. ASSISTANT OFFICE | SUBJECT: | 12/4/24 at 12:41 PM | | | | | | | | |
| CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-054 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: 128 - GARAGE MANAGER OFFICE | SUBJECT: 12/4/24 at 12:41 PM | |
| | CATEGORY: Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------|------------------------------|---------------------------------------------------------------------------------------|
| 029-055 | <p>Glazed curtain wall installation in progress.</p> | |  |
| | SPACE: 131 - CIRCULATION | SUBJECT: 12/4/24 at 12:42 PM | |
| | CATEGORY: Glazed Curtain Walls | REFERENCE: 084413 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-056 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | |
| | SPACE: | 107 - CIRCULATION | SUBJECT: | 12/4/24 at 12:45 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-057 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | |
| | SPACE: | 103 - CIRCULATION | SUBJECT: | 12/4/24 at 12:45 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------------------------|------------|---------------------|
| 029-058 | <p>Non structural metal framing installation in progress.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | | |
| | SPACE: | 101 - RECEPTION / GREETING AREA | | SUBJECT: | 12/4/24 at 12:46 PM |
| | CATEGORY: | Non Structural Metal Framing / Gypsum Board | | REFERENCE: | 092216 / 092900 |

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|---------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|---------------------------------------------------------------------------------------|------------|---------------------|
| 029-059 | <p>Metal pan stair installation in progress.</p> <p>Glazed decorative metal guardrail installation in progress.</p> | |  | | |
| | SPACE: | 102 - STAIR A | | SUBJECT: | 12/4/24 at 12:46 PM |
| | CATEGORY: | Metal Pan Stairs / Glazed Decorative Metal Railings | | REFERENCE: | 055113 / 057313 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------|----------------|-------------------------------------------------------------------------------------|
| 029-060 | Ceramic tile installation in progress. | |  |
| | SPACE: | 105 - JANITOR | SUBJECT: 12/4/24 at 12:47 PM |
| | CATEGORY: | Ceramic Tiling | REFERENCE: 093013 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------|------------------------------|-------------------------------------------------------------------------------------|
| 029-061 | Ceramic tile installation in progress. | |  |
| | SPACE: | 106 - PUBLIC FEMALE RESTROOM | SUBJECT: 12/4/24 at 12:47 PM |
| | CATEGORY: | Ceramic Tiling | REFERENCE: 093013 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-062 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 162 - CIRCULATION | SUBJECT: | 12/4/24 at 12:48 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-063 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 172 - CIRCULATION | SUBJECT: | 12/4/24 at 12:49 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-064 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: 172 - CIRCULATION | SUBJECT: 12/4/24 at 12:49 PM | |
| | CATEGORY: Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-065 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 172 - CIRCULATION | SUBJECT: | 12/4/24 at 12:49 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-066 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Acoustical panel next to storefront does not appear to be level. Double check that pane is level, ties into storefront mullion.</p> | |  |
| | SPACE: | 171 - CONFERENCE ROOM | SUBJECT: 12/4/24 at 12:50 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-067 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  |
| | SPACE: | 171 - CONFERENCE ROOM | SUBJECT: 12/4/24 at 12:50 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-068 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 162 - CIRCULATION | SUBJECT: | 12/4/24 at 12:50 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-069 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 162 - CIRCULATION | SUBJECT: | 12/4/24 at 12:51 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-070 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | |
| | SPACE: | 173 - BUG ROOM 2 | SUBJECT: | 12/4/24 at 12:52 PM |
| | CATEGORY: | Joint Sealants / Acoustical Ceiling / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-071 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Overhead coiling door installation in progress.</p> | |  | |
| | SPACE: | 174 - IMAGE ROOM | SUBJECT: | 12/4/24 at 12:52 PM |
| | CATEGORY: | Joint Sealants / Coiling Doors / Painting | REFERENCE: | 079200 / 083323 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------------------------------|-----------------------------|
| 029-072 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is complete.</p> <p>Storefront framing installation in progress.</p> | |  | |
| | SPACE: | 174 - IMAGE ROOM | SUBJECT: | 12/4/24 at 12:52 PM |
| | CATEGORY: | Joint Sealants / Storefront Framing / Painting | REFERENCE: | 079200 / 084113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-073 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Pipe and tube guardrail installation in progress.</p> | |  | |
| | SPACE: | 183 - WAREHOUSE | SUBJECT: | 12/4/24 at 12:53 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: | 055213 / 079200 / 099123 |


Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-074 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint installation is in progress.</p> <p>Pipe and tube guardrail installation in progress.</p> | |  | |
| | SPACE: | 183 - WAREHOUSE | SUBJECT: | 12/4/24 at 12:54 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: | 055213 / 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | | PHOTO |
|-----------|---------------------------------------------------------------------------------------------|--------------------|------------|-------------------------------------------------------------------------------------|
| 029-075 | Beam support metal fabrication installation in progress. Paint same color as wall color. | | |  |
| SPACE: | | 183 - WAREHOUSE | SUBJECT: | 12/4/24 at 12:54 PM |
| CATEGORY: | | Metal Fabrications | REFERENCE: | 055000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-076 | <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | |
| | SPACE: | 108 - CIRCULATION | SUBJECT: | 12/4/24 at 12:55 PM |
| | CATEGORY: | Joint Sealants / Gypsum Board / Painting | REFERENCE: | 079200 / 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-077 | Pipe and tube railing installation in progress. Storefront framing installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 157 - WORK SPACE CARPENTRY | SUBJECT: 12/4/24 at 12:56 PM | |
| | CATEGORY: Pipe and Tube Railings / Storefront Framing / Painting | REFERENCE: 055213 / 084113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------------------------------------|
| 029-078 | Pipe and tube railing installation in progress. Storefront framing installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 154 - WORK SPACE PLUMBING | SUBJECT: 12/4/24 at 12:56 PM | |
| | CATEGORY: Pipe and Tube Railings / Storefront Framing / Painting | REFERENCE: 055213 / 084113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-079 | Storefront installation in progress. Sectional door installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 154 - WORK SPACE PLUMBING | SUBJECT: 12/4/24 at 12:56 PM | |
| | CATEGORY: Storefront Framing / Sectional Doors / Painting | REFERENCE: 084113 / 083613 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------------------------------------|
| 029-080 | Storefront installation in progress. Sectional door installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 154 - WORK SPACE PLUMBING | SUBJECT: 12/4/24 at 12:57 PM | |
| | CATEGORY: Storefront Framing / Sectional Doors / Painting | REFERENCE: 084113 / 083613 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-081 | <p>Pipe and tube railing installation in progress.</p> <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint finish in progress.</p> | |  | |
| | SPACE: | 226 - MEZZANINE | SUBJECT: | 12/4/24 at 12:58 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: | 055213 / 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | | PHOTO |
|-----------|---------------------------------------------------------------------------------------------|------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-082 | Beam support metal fabrication installation in progress. Paint same color as wall color. | | |  |
| SPACE: | | 154 - WORK SPACE PLUMBING | SUBJECT: | 12/4/24 at 12:59 PM |
| CATEGORY: | | Metal Fabrications | REFERENCE: | 055000 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------|
| 029-083 | <p>Pipe and tube railing installation in progress.</p> <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint finish in progress.</p> | |  | |
| | SPACE: | 226 - MEZZANINE | SUBJECT: | 12/4/24 at 12:59 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: | 055213 / 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-084 | <p>Pipe and tube railing installation in progress.</p> <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint finish in progress.</p> | |  |
| | SPACE: | 229 - MAINTENANCE STORAGE | SUBJECT: 12/4/24 at 1:01 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: 055213 / 079200 / 099123 |

Site Visit - Construction Observation


DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-085 | <p>Pipe and tube railing installation in progress.</p> <p>Joint sealant installation in progress. Install joint sealant perimeter of concrete floor slab.</p> <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>Exposed structure paint finish in progress.</p> | |  |
| | SPACE: | 229 - MAINTENANCE STORAGE | SUBJECT: 12/4/24 at 1:02 PM |
| | CATEGORY: | Pipe and Tube Railings / Joint Sealants / Painting | REFERENCE: 055213 / 079200 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------------|
| 029-086 | Pipe and tube railing installation in progress. Storefront framing installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 229 - MAINTENANCE STORAGE | SUBJECT: 12/4/24 at 1:02 PM | |
| | CATEGORY: Pipe and Tube Railings / Storefront Framing / Painting | REFERENCE: 055213 / 084113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|--------------------------------------------------------------------------------------|
| 029-087 | Pipe and tube railing installation in progress. Storefront framing installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: 229 - MAINTENANCE STORAGE | SUBJECT: 12/4/24 at 1:03 PM | |
| | CATEGORY: Pipe and Tube Railings / Storefront Framing / Painting | REFERENCE: 055213 / 084113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------|-------------------------|-------------------------------------------------------------------------------------|
| 029-088 | Paint installation complete. Electrical installation in progress. | |  |
| | SPACE: | 227 - ELECTRICAL CLOSET | SUBJECT: 12/4/24 at 1:04 PM |
| | CATEGORY: | Painting / Electrical | REFERENCE: 099123 / 260000 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|--------------------------------------------------------------------------------------|
| 029-089 | Pipe and tube railing installation in progress. Storefront framing installation in progress. Exposed structure painting in progress. | |  |
| | SPACE: | 226 - MEZZANINE | SUBJECT: 12/4/24 at 1:04 PM |
| | CATEGORY: | Pipe and Tube Railings / Storefront Framing / Painting | REFERENCE: 055213 / 084113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------------------------|------------|--------------------|
| 029-090 | <p>Non structural metal framing installation in progress.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | | |
| | SPACE: | 201 - CIRCULATION | | SUBJECT: | 12/4/24 at 1:05 PM |
| | CATEGORY: | Non Structural Metal Framing / Gypsum Board | | REFERENCE: | 092216 / 092900 |

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|---------------------------------------------------------------------------------------|------------|--------------------|
| 029-091 | <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | | |
| | SPACE: | 204 - KITCHEN | | SUBJECT: | 12/4/24 at 1:06 PM |
| | CATEGORY: | Gypsum Board / Acoustical Ceiling | | REFERENCE: | 092900 / 095113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------------------------|------------|--------------------|
| 029-092 | <p>Non structural metal framing installation in progress.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | | |
| | SPACE: | 201 - CIRCULATION | | SUBJECT: | 12/4/24 at 1:06 PM |
| | CATEGORY: | Non Structural Metal Framing / Gypsum Board | | REFERENCE: | 092216 / 092900 |

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|---------------------------------------------------------------------------------------|------------|--------------------|
| 029-093 | <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> <p>Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113.</p> | |  | | |
| | SPACE: | 205 - LARGE TRAINING ROOM | | SUBJECT: | 12/4/24 at 1:06 PM |
| | CATEGORY: | Gypsum Board / Acoustical Ceiling | | REFERENCE: | 092900 / 095113 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-094 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 207 - TRANSPORTATION ASSISTANT DIRECTOR | SUBJECT: 12/4/24 at 1:07 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-095 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 208 - TRANSPORTATION DIRECTOR | SUBJECT: 12/4/24 at 1:07 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|-------------------------------------------------------------------------------------|
| 029-096 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: | 205 - LARGE TRAINING ROOM | SUBJECT: 12/4/24 at 1:07 PM |
| | CATEGORY: | Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------------------------------------------------------------------------------|
| 029-097 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: | 206 - WORK AREA | SUBJECT: 12/4/24 at 1:08 PM |
| | CATEGORY: | Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-098 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 209 - CLERICAL ASSISTANT 1 | SUBJECT: 12/4/24 at 1:08 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-099 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 210 - CLERICAL ASSISTANT 2 | SUBJECT: 12/4/24 at 1:08 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-100 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 211 - CLERICAL ASSISTANT 3 | SUBJECT: 12/4/24 at 1:08 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-101 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 214 - AREA COORDINATOR 2 | SUBJECT: 12/4/24 at 1:09 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029


| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-102 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 213 - CONFERENCE ROOM | SUBJECT: 12/4/24 at 1:09 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-103 | Acoustical panel ceiling installation in progress. Install per part 3 execution specification section 095113. Paint installation in progress. | |  |
| | SPACE: 202 - CIRCULATION | SUBJECT: 12/4/24 at 1:10 PM | |
| | CATEGORY: Acoustical Ceiling / Painting | REFERENCE: 095113 / 099123 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------------------------|------------|--------------------|
| 029-104 | <p>Non structural metal framing installation in progress.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | |  | | |
| | SPACE: | 201 - CIRCULATION | | SUBJECT: | 12/4/24 at 1:10 PM |
| | CATEGORY: | Non Structural Metal Framing / Gypsum Board | | REFERENCE: | 092216 / 092900 |

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|-----------------------------------------------------------------------------------------------|-------------------------------------------|---------------------------------------------------------------------------------------|------------|--------------------|
| 029-105 | <p>Metal pan stair installation in progress. Pipe and tube rail installation in progress.</p> | |  | | |
| | SPACE: | 111 - STAIR B | | SUBJECT: | 12/4/24 at 1:12 PM |
| | CATEGORY: | Metal Pan Stairs / Pipe and Tube Railings | | REFERENCE: | 055113 / 055213 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | | PHOTO |
|-----------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-106 | <p>Non structural metal framing installation in progress.</p> <p>Gypsum board installation in progress. Install per part 3 execution specification section 092900. Provide level 4 finish per specification section 092900 3.6 D.</p> | | |  |
| SPACE: | | 203 - CIRCULATION | SUBJECT: | 12/4/24 at 1:12 PM |
| CATEGORY: | | Non Structural Metal Framing / Gypsum Board | REFERENCE: | 092216 / 092900 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | | | | | | | |
|-----------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|----------|--------------------|-----------|------------------------------|------------|--------------------------|--|--|
| 029-107 | <p>Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable.</p> <p>HVAC and Electrical installation in progress.</p> | |  | | | | | | | | |
| | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">SPACE:</td> <td style="width: 50%;">225 - MECHANICAL / ELECTRICAL ROOM</td> <td style="width: 25%;">SUBJECT:</td> <td style="width: 20%;">12/4/24 at 1:12 PM</td> </tr> <tr> <td>CATEGORY:</td> <td>Painting / HVAC / Electrical</td> <td>REFERENCE:</td> <td>099123 / 230000 / 260000</td> </tr> </table> | SPACE: | 225 - MECHANICAL / ELECTRICAL ROOM | SUBJECT: | 12/4/24 at 1:12 PM | CATEGORY: | Painting / HVAC / Electrical | REFERENCE: | 099123 / 230000 / 260000 | | |
| SPACE: | 225 - MECHANICAL / ELECTRICAL ROOM | SUBJECT: | 12/4/24 at 1:12 PM | | | | | | | | |
| CATEGORY: | Painting / HVAC / Electrical | REFERENCE: | 099123 / 230000 / 260000 | | | | | | | | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|-------------------------------------------------------------------------------------|------------|--------------------------|
| 029-108 | Paint installation in progress. Refer to Pro Industrial Heavy Duty Block Filler by Sherwin Williams. Install per manufacturer Application instructions and approved shop drawings. Install to provide a pinhole free surface per manufacture instructions. Current application is not acceptable. HVAC and Electrical installation in progress. | |  | | |
| | SPACE: | 225 - MECHANICAL / ELECTRICAL ROOM | | SUBJECT: | 12/4/24 at 1:13 PM |
| | CATEGORY: | Painting / HVAC / Electrical | | REFERENCE: | 099123 / 230000 / 260000 |

| ITEM | REMARKS | DISCUSSION | PHOTO | | |
|---------|------------------------------------------------------------------------------------------------|---------------------|---------------------------------------------------------------------------------------|------------|--------------------|
| 029-109 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  | | |
| | SPACE: | 009 - ROOF - OFFICE | | SUBJECT: | 12/4/24 at 1:14 PM |
| | CATEGORY: | Roof Specialties | | REFERENCE: | 077100 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------|---------------------|-------------------------------------------------------------------------------------|
| 029-110 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: | 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:15 PM |
| | CATEGORY: | Roof Specialties | REFERENCE: 077100 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------|---------------------|-------------------------------------------------------------------------------------|
| 029-111 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: | 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:15 PM |
| | CATEGORY: | Roof Specialties | REFERENCE: 077100 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------|---------------------------------------------------------------------------------------|
| 029-112 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. Ensure joints are properly sealed. Ensure cut panels are straight. | |  |
| | SPACE: | 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:15 PM |
| | CATEGORY: | Roof Specialties | REFERENCE: 077100 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|-------------------------------------------------------------------------------------|
| 029-113 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. Damaged SBS roofing has been repaired. | |  |
| | SPACE: | 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:16 PM |
| | CATEGORY: | SBS Roofing / Roof Specialties | REFERENCE: 075216 / 077100 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------|---------------------|--------------------------------------------------------------------------------------|
| 029-114 | Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: | 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:17 PM |
| | CATEGORY: | Roof Specialties | REFERENCE: 077100 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------------------------------------|-----------------------------|
| 029-115 | Standing seam metal roof installation in progress. Install snow guards per approved shop drawings. Coordinate snow guard location with roof penetrations and lighting protection. | |  | |
| | SPACE: | 011 - ROOF - BUS MAINTENENACE - RADIUS | | SUBJECT: 12/4/24 at 1:18 PM |
| | CATEGORY: | Standing Seam Metal Roof Panels / Snow Guards | | REFERENCE: 074113 / 077253 |

| ITEM | REMARKS | DISCUSSION | PHOTO | |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------|---------------------------------------------------------------------------------------|-----------------------------|
| 029-116 | Standing seam metal roof installation in progress. Install snow guards per approved shop drawings. Coordinate snow guard location with roof penetrations and lighting protection. | |  | |
| | SPACE: | 013 - ROOF - OPERATIONS / IT - RADIUS | | SUBJECT: 12/4/24 at 1:18 PM |
| | CATEGORY: | Standing Seam Metal Roof Panels / Snow Guards | | REFERENCE: 074113 / 077253 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-----------------------------------------------------------------------------------|
| 029-117 | SBS roofing installation in progress. Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:19 PM | |
| | CATEGORY: SBS Roofing / Roof Specialties | REFERENCE: 075216 / 077100 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|------------------------------------------------------------------------------------|
| 029-118 | SBS roofing installation in progress. Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:19 PM | |
| | CATEGORY: SBS Roofing / Roof Specialties | REFERENCE: 075216 / 077100 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-119 | SBS roofing installation in progress. Wall coping installation in progress. Ensure continuous front and rear cleats are provided. | |  |
| | SPACE: 009 - ROOF - OFFICE | SUBJECT: 12/4/24 at 1:20 PM | |
| | CATEGORY: SBS Roofing / Roof Specialties | REFERENCE: 075216 / 077100 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-120 | Unit masonry is damaged at door jamb 103A. | |  |
| | SPACE: 103 - CIRCULATION | SUBJECT: 12/4/24 at 1:28 PM | |
| | CATEGORY: Unit Maosnry | REFERENCE: 042000 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-121 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction
Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 001 - NORTH ELEVATION | SUBJECT: | 12/4/24 at 1:31 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-122 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:32 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-123 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:32 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-124 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:33 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-125 | <p>Provide repairing, pointing, and cleaning per specification section 042000.</p> <p>Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints.</p> <p>Remove all mortar from face of masonry units.</p> <p>Provide final cleaning.</p> <p>Clean per manufacturer instructions.</p> <p>Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5.</p> <p>Provide final cleaning per specification section 047200.</p> <p>Remove all mortar / stains from cast stone masonry.</p> <p>Clean per manufacturer instructions.</p> <p>Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323.</p> <p>Provide adjusting and cleaning per specification section 047323.</p> <p>Clean per manufacturer instructions.</p> <p>Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:33 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-126 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction
Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:34 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-127 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction
Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:34 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-128 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
VISIT NAME: Construction Progress Site Visit
REPORT NO: 029

| | | | |
|-------------------------------------------------------------------|-------------------------------------------|------------|--------------------------|
| cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 002 - SOUTH ELEVATION | SUBJECT: | 12/4/24 at 1:35 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-129 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| | | | |
|-----------|-------------------------------------------------------------------|------------|--------------------------|
| | cleaning method that will damage or discolor stone masonry units. | | |
| SPACE: | 002 - SOUTH ELEVATION | SUBJECT: | 12/4/24 at 1:35 PM |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 042000 / 047200 / 047323 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-130 | <p>Column cover installation in progress.</p> <p>Metal wall panel installation in progress. Metal wall panels adjacent to the end column covers shall match the color of the column covers.</p> <p>Paint touch-up damaged exposed structural painting next to column cover.</p> | |  |
| | SPACE: 003 - EAST ELEVATION | SUBJECT: | 12/4/24 at 1:36 PM |
| | CATEGORY: Column Covers / Metal Wall Panels / Painting | REFERENCE: | 055813 / 074213 / 099123 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-131 | <p>Provide repairing, pointing, and cleaning per specification section 042000. Provide pointing per specification section 042000 3.14 B. Ensure there are no holes in the mortar joints. Remove all mortar from face of masonry units. Provide final cleaning. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor masonry units.</p> <p>Provide adjusting and cleaning per specification section 047200 3.5. Provide final cleaning per specification section 047200. Remove all mortar / stains from cast stone masonry. Clean per manufacturer instructions. Do not use cleaner or cleaning method that will damage or discolor cast stone units.</p> <p>Provide field quality control per specification section 047323. Provide adjusting and cleaning per specification section 047323. Clean per manufacturer instructions. Do not use cleaner or</p> | |  |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| | | | | |
|-----------|-------------------------------------------------------------------|------------|--------------------------|--|
| | cleaning method that will damage or discolor stone masonry units. | | | |
| SPACE: | 002 - SOUTH ELEVATION | SUBJECT: | 12/4/24 at 1:37 PM | |
| CATEGORY: | Unit Masonry / Cast Stone / Stone Masonry | REFERENCE: | 055813 / 074213 / 099123 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|-----------|--------------------------------------------|------------|-------------------------------------------------------------------------------------|
| 029-132 | Pavement marking installation in progress. | |  |
| SPACE: | 006 - SITE - SOUTH | SUBJECT: | 12/4/24 at 1:38 PM |
| CATEGORY: | Pavement Markings | REFERENCE: | 321723 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|-----------|--------------------------------------------|------------|---------------------------------------------------------------------------------------|
| 029-133 | Pavement marking installation in progress. | |  |
| SPACE: | 006 - SITE - SOUTH | SUBJECT: | 12/4/24 at 1:39 PM |
| CATEGORY: | Pavement Markings | REFERENCE: | 321723 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------|--------------------|-------------------------------------------------------------------------------------|
| 029-134 | Pavement marking installation in progress. | |  |
| | SPACE: | 006 - SITE - SOUTH | SUBJECT: 12/4/24 at 1:39 PM |
| | CATEGORY: | Pavement Markings | REFERENCE: 321723 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------|-------------------|-------------------------------------------------------------------------------------|
| 029-135 | Pavement marking installation in progress. | |  |
| | SPACE: | 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:40 PM |
| | CATEGORY: | Pavement Markings | REFERENCE: 321723 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------|-------------------|---------------------------------------------------------------------------------------|
| 029-136 | Pavement marking installation in progress. | |  |
| | SPACE: | 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:40 PM |
| | CATEGORY: | Pavement Markings | REFERENCE: 321723 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|-------------------------------------------------------------------------------------|
| 029-137 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: | 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:40 PM |
| | CATEGORY: | Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|--------------------------------------------------------------------------------------|
| 029-138 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: | 006 - SITE - SOUTH | SUBJECT: 12/4/24 at 1:41 PM |
| | CATEGORY: | Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|-------------------------------------------------------------------------------------|
| 029-139 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: | 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:42 PM |
| | CATEGORY: | Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|--------------------------------------------------------------------------------------|
| 029-140 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: | 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:42 PM |
| | CATEGORY: | Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------|
| 029-141 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: 008 - SITE - WEST | SUBJECT: 12/4/24 at 1:42 PM | |
| | CATEGORY: Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 | |

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|--------------------------------------------------------------------------------------|
| 029-142 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. | |  |
| | SPACE: 005 - SITE - NORTH | SUBJECT: 12/4/24 at 1:43 PM | |
| | CATEGORY: Asphalt Paving / Pavement Markings | REFERENCE: 321216 / 321723 | |

Site Visit - Construction Observation

DATE: 12/4/2024
 VISIT NAME: Construction
 Progress Site Visit
 REPORT NO: 029

| ITEM | REMARKS | DISCUSSION | PHOTO |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------------------------------|
| 029-143 | Asphalt installation complete. Clean and remove construction markings from asphalt surface. Pavement marking installation in progress. Security fencing installation in progress. Install fencing per approved shop drawings and construction documents. | |  |
| | SPACE: | 005 - SITE - NORTH | SUBJECT: 12/4/24 at 1:45 PM |
| | CATEGORY: | Asphalt Paving / Pavement Markings / Security Fences | REFERENCE: 321216 / 321723 / 323113 |

TO:

| | |
|------------------|-------------------------------|
| Carrie Hooten | Kenton County School District |
| Kevin Pfefferman | Kenton County School District |
| Matthew Rigg | Kenton County School District |
| Brian Vanover | Kenton County School District |

COPIES:

| | |
|--------------------|------------------------------|
| Seth Mittle | GRW |
| David Vaught | GRW |
| Todd Cantrell | GRW |
| Mike McReynolds | GRW |
| Jon Sheppard | GRW |
| Jim Adams | Facility Commissioning Group |
| Adolph Zell | Morel Construction |
| Anthony Berkemeier | Morel Construction |